

5 yearly performance review - Refer to section 6

ERM Power Limited
Neerabup Gas-fired Power Station
Compliance Assessment Report and 5 Year
Performance Review –
Ministerial Statement 759

6 January 2020

57594-124796

JBS&G Australia Pty Ltd T/A Strategen-JBS&G

Table of Contents

1.	Introduction	1
1.1	Project background	1
2.	Current status	2
3.	Audit methodology	3
3.1	Audit plan	3
3.1.1	Purpose and scope	3
3.1.2	Methodology	4
3.2	Audit terminology	4
4.	Audit results	5
4.1	Compliance with conditions	5
5.	Environmental monitoring	6
6.	Performance Review	7
6.1	Environmental issues associated with project implementation	7
6.2	Achieving environmental performance	8
6.3	Improvements in environmental management	9
6.4	Stakeholder and community consultation	10
6.5	Forecasted environmental objectives	10
7.	Stakeholder consultation	11
8.	Limitations	12
9.	References	13

List of Tables

Table 3.1:	Action implementation status	4
Table B.1:	Compliance with MS 759	3
Table C.1:	Schedule 1 of MS 759 audit table	12
Table E.1:	Greenhouse Gas Abatement Programme audit table	18

Appendices

Appendix A	Statement of Compliance
Appendix B	MS 759 audit table
Appendix C	MS 759 Schedule 1 audit table
Appendix D	Stack Emissions Management Plan Rev 2.0 (20 June 2013) audit table
Appendix E	Greenhouse Gas abatement Programme audit table
Appendix F	Banker’s Audit

1. Introduction

This report addresses the status and compliance of the Neerabup Gas-Fired Power Station with conditions in Ministerial Statement (MS) 759. This report has been prepared for the purpose of meeting the requirements of condition 4-1 of MS 759, which requires submission of an annual Compliance Assessment Report (CAR).

Appendix F of this report also addresses the status and compliance of the Neerabup Gas-Fired Power Station with the conditions of various environmental and planning approvals and has been prepared to meet a requirement of the “Banker’s conditions” to submit an annual compliance report.

1.1 Project background

NewGen Neerabup Partnership (NewGen) is the Proponent for a proposal to construct and operate:

- a 330 megawatt open-cycle gas-turbine power station
- a 30 kilometre long gas pipeline and compressor station to transport natural gas from the Dampier to Bunbury Natural Gas Pipeline to the power station
- a 330 kilovolt electricity transmission line, approximately two kilometres long, to connect the power station to the Western Power Neerabup terminal substation.

The Minister for the Environment issued MS 759 on 21 January 2008, under Part IV of the *Environmental Protection Act 1986* (EP Act), enabling the proposal to be implemented. A number of subsequent environmental and planning approvals have also been granted.

The power station is located at Neerabup, approximately 30 km north of Perth. The power station provides additional power into the South West Interconnected System (SWIS) during times of peak demand.

NewGen led the development and project financing for the Neerabup power station. ERM Power was the project and construction manager and is currently the operator of the facility.

2. Current status

Construction of the power station, gas pipeline and transmission line was completed in 2009, and the power station officially opened on 3 December 2009. The power station has been supplying power into the South-West Interconnected System (SWIS; as requested by Synergy) since that time.

The 330-kilovolt electricity transmission line was handed over to Western Power on 11 March 2010 and was officially published in the WA Government Gazette on 19 March 2010.

NewGen remains the proponent of the Gas-Fired Power Station, transmission line and natural gas pipeline. ERM Power is the operator/manager of the power station and pipeline facilities. Typically, power station operations consist of infrequent very short run durations. During the reporting period a total of 200 starts were recorded between the two units (11 and 12), with a 6.18% total operating capacity factor for the reporting financial year.

3. Audit methodology

3.1 Audit plan

3.1.1 Purpose and scope

This CAR has been prepared for NewGen (the proponent) to fulfil the requirements of condition 4-1 of MS 759, issued for the Neerabup Gas-Fired Power Station proposal. Condition 4-1 requires the proponent to submit an annual CAR (on the previous twelve-month period) to the Chief Executive Officer (CEO) of the Department of Water and Environmental Regulation (DWER) (previously the Office of the Environmental Protection Authority [OEPA]).

Condition 4-2 requires the report to address each element of an approved audit program and be in an acceptable format.

Condition 4-3 requires the report to:

1. Be endorsed by signature of the proponent's Chief Executive Officer or a person, approved in writing by the CEO, delegated to sign on behalf of the proponent's CEO.
2. State whether the proponent has complied with each condition and procedure contained in this statement.
3. Provide verifiable evidence of compliance with each condition and procedure contained in this statement.
4. State whether the proponent has complied with each key action contained in any environmental management plan or program required by this statement.
5. Provide verifiable evidence of conformance with each key action contained in any environmental management plan or program required by this statement.
6. Identify all non-compliances and non-conformances and describe the corrective and preventative actions taken in relation to each non-compliance or non-conformance.
7. Review the effectiveness of all corrective and preventative actions taken.
8. Describe the state of implementation of the proposal.

Conditions 4-3.2 and 4-3.3 refer to complying with procedures contained in MS 759 and providing verifiable evidence of compliance with the procedures. MS 759 does not contain any procedures and these requirements are consequently not applicable to this audit.

Conditions 4-3.4 and 4-3.5 refer to conformance with key actions within any environmental management plan or program required by MS 759. The plans and programs required to be implemented are:

- Rehabilitation Management Plan (RMP)
- Stack Emissions Management Plan (SEMP)
- Greenhouse Gas Abatement Programme (GGAP).

Key implementation actions of the RMP have been completed and are no longer audited. The status of implementation of the SEMP and GGAP is provided in Appendix D and Appendix E, respectively.

In addition, a third-party annual compliance review is required to address Banker's conditions. The Banker's audit, presented in Appendix F, has been undertaken as part of this CAR; incorporating the MS, subsidiary management plans and additional environmental approvals including:

- operating licence L8356/2009/2
- groundwater licence GWL164093(3).

The audit period relevant to this CAR and Banker’s audit is 1 July 2018 to 30 June 2019.

3.1.2 Methodology

The site inspection component of the audit was undertaken by Elizabeth Payne (Senior Consultant, Strategen-JBS&G) and Rebecca Mason (Consultant, Strategen-JBS&G) on 29 October 2019 and included discussion and review of key documents with Bruno Lanciano, Neerabup Power Station Manager, ERM Power.

3.2 Audit terminology

The ‘Status’ field of the audit tables (refer to Appendix B - Appendix E) describes the implementation of actions and compliance with the Statement. This report has been prepared using guidance related to the preparation of compliance audits, including generic expressions that are used to identify the status of each action (Table 3.1). The terminology in Table 3.1 has been applied to complete the status field of the audit tables given in Appendix B - Appendix E.

Table 3.1: Action implementation status

Status	Description
Compliant/conformant.	Implementation of the proposal has been carried out in accordance with requirements of the audit element.
Completed.	A requirement with a finite period of application has been satisfactorily completed.
Not required at this stage.	The requirements of the audit element were not triggered during the reporting period.
Potentially non-compliant/Potentially non-conformant.	Possible or likely failure to meet the requirements of the audit element.
In process.	Where an audit element requires a management or monitoring plan be submitted to the OEPA or another government agency for approval, that submission has been made and no further information or changes have been requested by the OEPA or the other government agency and assessment by the OEPA or other government agency for approval is still pending.
Not audited.	Unable to be audited.

Source: Adapted from OEPA (2012a, 2012b, 2012c and 2012d) – note that the ‘Not audited’ status has been added for items that were unable to be audited.

4. Audit results

4.1 Compliance with conditions

A signed Statement of Compliance is provided in Appendix A.

The results of the audit for MS 759 are presented in Appendix B.

Condition 1-1 of MS 759 requires implementation of the proposal as documented in Schedule 1 and Schedule 2 of MS 759. The results of the audit of implementation of the key characteristics contained in Schedule 1 are outlined in Appendix C. Schedule 2 has been completed as discussed in Appendix C item 759 M10.1.

Condition 4-3 requires each key action contained in any management plan/program to be audited. The results of the audit of key actions in the SEMP and GGAP are outlined in Appendix D and Appendix E.

Results of the audit of key actions of the Banker's audit including the operating licence L8356/2009/2 and groundwater licence GWL164093(3) are outlined in Appendix F.

5. Environmental monitoring

A range of monitoring programs have been undertaken during the audit period, as required by the various management plans and licences. Monitoring includes:

- air emissions monitoring in accordance with the Stack Emissions Management Plan (SEMP) and operating licence administered by DWER (previously Department of Environment Regulation [DER])
- groundwater monitoring in accordance with the operating licence and the abstraction licence administered by DWER
- greenhouse gas emissions monitoring and reporting in accordance with National Greenhouse and Energy Reporting Scheme (NGERS).

6. Performance Review

Condition 5-1 of MS 759 requires that:

The proponent shall submit a Performance Review report every five years after the start of production to the Environmental Protection Authority, which addresses:

1. *The major environmental issues associated with implementing the project; the environmental objectives for those issues; the methodologies used to achieve these; and the key indicators of environmental performance measured against those objectives;*
2. *The level of progress in the achievement of sound environmental performance, including industry benchmarking, and the use of best available technology where practicable;*
3. *Significant improvements gained in environmental management, including the use of external peer reviews;*
4. *Stakeholder and community consultation about environmental performance and the outcomes of that consultation, including a report of any on-going concerns being expressed;*
and
5. *The proposed environmental objectives over the next five years, including improvements in technology and management processes.*

The timing for this Performance Review has now been reached within this audit period and the results of the five-year performance review are presented below.

6.1 Environmental issues associated with project implementation

In accordance with Condition 5-1 (1) of MS 759, the following components must be addressed:

- environmental issues associated with implementing the project
- the environmental objectives for those environmental issues
- methods used to achieve environmental objectives
- key indicators of environmental performance measured against environmental objectives.

The significant environmental issues relating to the Neerabup Gas-Fired Power Station, and the environmental factors associated with these issues, were identified utilising EPA guidelines and preliminary stakeholder engagement. A summary of the potential environmental issues and environmental factors are given below:

- air quality
- flora and vegetation
- terrestrial environmental quality
- social surroundings
- hydrological processes
- inland waters environmental quality
- human health

Prior to ground disturbing activities a Rehabilitation Management Plan was prepared to encompass the following protocols and criteria:

- weed management
- dieback management

- soil management
- rehabilitation completion criteria
- the need for propagule augmentation to achieve completion criteria.

To ensure rehabilitation meets EPA requirements, the Gas pipeline and transmission lines were rehabilitated immediately following completion of works. Monitoring of rehabilitation areas was undertaken in spring 2015 by Woodman Environmental. The monitoring report stated that plant density criterion levels and criteria for native vegetation development were reached by all sections of the Right of Way (RoW). DWER (formally OEPA) confirmed in November 2015 that rehabilitation met the DWER requirements and that rehabilitation completion criteria had been met.

Key objectives and performance indicators for managing air emissions are outlined in the SEMP. Environmental objectives include:

- ensure that emissions do not adversely affect environmental values or the health, welfare and amenity of people and land users by meeting statutory requirements and acceptable standards
- ensure that best available practicable and efficient technologies are used to minimise and monitor air emissions from the power station

Monitoring of air emissions is undertaken in accordance with the SEMP and include targets for:

- atmospheric emissions concentrations
- start-up cycles
- ambient air quality.

All emissions testing performed to date has verified that emissions measured are below targets. Greenhouse gases emissions as a result of operations are managed in accordance with the Greenhouse Gas Abatement Program (GGAP). Compliance is continually maintained with relevant NEPM guidelines and greenhouse gas reporting aligned with NGRS.

6.2 Achieving environmental performance

In accordance with Condition 5-1 (2) of MS 759, the following components must be incorporated in relation to the level of progress in the achievement of sound environmental performance:

- industry benchmarking
- use of best available technology (where practicable).

Industry benchmarking and use of best available technology (where practicable) was addressed in the design and construction of the plant in 2009. In summary, the plant incorporated best practice in the following ways:

- operation of the power plant
- design of the power plant.

The Neerabup Gas-fired Power Station only uses natural gas as the fuel source for operation. Natural gas produces fewer atmospheric emissions compared to using diesel or coal, including less greenhouse gases, oxides of nitrogen and sulphur dioxide. This means that the low emission natural gas fuel source can be piped directly to the site so that the power station can be located close to the centre of demand such as the metropolitan area. Less energy is also lost through the transmission of electricity.

The Neerabup Gas-fired Power Station also has a faster start up time (typically less than 15 minutes) compared to coal fired units (up to 24 hours) which makes the power plant more efficient in terms of production as it meets peak and high shoulder load demands.

The Neerabup Gas-fired Power Station has a smaller footprint (4 ha of cleared farming land) and requires minimal supporting infrastructure which resulted in a smaller footprint area compared to conventional peak loading power plants.

The operator configured the Supervisory Control and Data Acquisition (SCADA) system in July 2015 to provide real-time monitoring of thermal efficiency. These monitoring results provide more accurate calculation of thermal efficiency recorded during operation.

Routine preventative maintenance and cleaning regimes is implemented to maintain operation of the power station at optimal efficiency. Maintenance planning schedules are in accordance with the manufacturer's requirements. Maintenance on the Neerabup gas turbines are triggered by the number of starts rather than the equivalent operating hours (EOH) due to the peaking nature of Neerabup Operations (short runs with frequent starts).

The Siemens OEM schedules minor inspections at 250 starts (+/- 10%) or 8,000EOH whichever is earlier. The most recent minor inspection, the second since operations began at the plant, occurred on the 10 and 7 of November 2017. At this time Unit 11 had accumulated 250 starts and unit 12 accumulated 251 starts between the 1st to the 2nd minor inspection (within OEM tolerance). The number of starts recorded since the first minor inspection in 2014 is in accordance with the projected number of starts outlined in the Neerabup Forecasted Inspection Plan 2009–2032. The Neerabup Forecasted Inspection Plan 2009–2032 indicates that the next minor inspections are scheduled for April 2020- October 2020.

Product and Service Bulletins are received by Siemens and are reviewed upon receipt, or at a minimum annually. These bulletins ensure that all corrections and operational specifications remain current. Correction work orders are included in the list of outstanding maintenance activities required to be undertaken during schedule maintenance outages.

Water washes can be undertaken within the compressor if routine efficiency monitoring shows it is required; i.e. a significant decrease in compressor efficiency. Efficiency monitoring tests are used to initiate any corrective maintenance required in accordance with ongoing preventative maintenance order (PM336) in the MEX system.

In regard to sustainability of industry benchmarking and use of the best available technology for the Neerabup Gas-fired Power Station, the Senior Site Manager continues to attend user group workshops including the following, and hold workshops to discuss best practice:

- v94.2 user group (mechanical)
- Siemens v94.2 Instrumentation and Electrical user group
- Siemens Instrumentation and Electrical user group.

6.3 Improvements in environmental management

In accordance with Condition 5-1 (3) of MS 759, significant improvements gained in environmental management, including the use of external peer reviews must be addressed in the Performance Review Report.

The Neerabup Gas-fired Power Station has not recorded any material non-conformances since its establishment in 2009. Improvements in environmental management are based around the operation and design of the power station.

Access to international forums is available to allow trouble shooting and sharing of information, which can include potential improvements in operations.

As mentioned previously, the company is represented at gas turbine user group functions which are specifically designed to address continual improvement. The operator is continuing to actively participate in the V94.2 group which is a group set up specifically for users of the V94.2 gas turbine allowing personnel to be made aware of advances in technology and share any initiatives. Recent attendance at the V94.2 conferences include:

- Bunbury in May 2015
- Brisbane in November 2016
- Rockhampton in February 2019
- Perth in March 2019.

6.4 Stakeholder and community consultation

In accordance with Condition 5-1 (4) of MS 759, the Performance Review report must address stakeholder and community consultation about environmental performance and the outcomes of that consultation. This includes a report of any on-going concerns being expressed.

A complaints procedure and complaints register procedure is implemented with a complaint register maintained. Additionally, annual stakeholder consultations are undertaken in accordance with the Stakeholder Management Guidelines Procedure. To date, no community complaints or ongoing concerns have been raised during the stakeholder and community consultation.

6.5 Forecasted environmental objectives

In accordance with Condition 5-1 (5) of MS 759, the proposed environmental objectives over the next five years, including improvements in technology and management processes must be addressed in the Performance Review Report.

Neerabup Gas-fired Power Station is to maintain compliance with all licences and approvals, including:

- MS 759
- Environmental Licence (L8356/2009/2)
- Licence to construct or alter well (CAW168369(1))
- Licence to take water (GWL164093(3))
- City of Wanneroo Development Approvals for the power station, gas pipeline and transmission line (DA07/1107 and DA08/0667, respectively)
- Western Australian Planning Commission Development Approvals for the power station, gas pipeline and transmission line (30-50179-1 and 30-50179-2, respectively).

The forecasted environmental objectives will continue to focus on emissions and maintaining compliance with relevant NEPM guidelines and NGERs.

7. Stakeholder consultation

ERM Power maintains a standard operating procedure for stakeholder management (NPS-PL-ROW-14), which requires that annual contact is made with each landowner or occupier to keep them informed of safety matters.

The following stakeholders were consulted during the audit period:

- adjacent land owners - Trandos farms
- pipeline land owners
- other Neerabup Industrial Estate neighbours
- WA Government Departments DWER and DMIRS, and Local Government, City of Wanneroo.

In addition, the SEMP covering the audit period was sent to DWER.

No complaints were received during the audit period between 1 July 2018 to 30 June 2019.

8. Limitations

Scope of services

This report ("the report") has been prepared by Strategen-JBS&G in accordance with the scope of services set out in the contract, or as otherwise agreed, between the Client and Strategen-JBS&G. In some circumstances, a range of factors such as time, budget, access and/or site disturbance constraints may have limited the scope of services. This report is strictly limited to the matters stated in it and is not to be read as extending, by implication, to any other matter in connection with the matters addressed in it.

Reliance on data

In preparing the report, Strategen-JBS&G has relied upon data and other information provided by the Client and other individuals and organisations, most of which are referred to in the report ("the data"). Except as otherwise expressly stated in the report, Strategen-JBS&G has not verified the accuracy or completeness of the data. To the extent that the statements, opinions, facts, information, conclusions and/or recommendations in the report ("conclusions") are based in whole or part on the data, those conclusions are contingent upon the accuracy and completeness of the data. Strategen-JBS&G has also not attempted to determine whether any material matter has been omitted from the data. Strategen-JBS&G will not be liable in relation to incorrect conclusions should any data, information or condition be incorrect or have been concealed, withheld, misrepresented or otherwise not fully disclosed to Strategen-JBS&G. The making of any assumption does not imply that Strategen-JBS&G has made any enquiry to verify the correctness of that assumption.

The report is based on conditions encountered and information received at the time of preparation of this report or the time that site investigations were carried out. Strategen-JBS&G disclaims responsibility for any changes that may have occurred after this time. This report and any legal issues arising from it are governed by and construed in accordance with the law of Western Australia as at the date of this report.

Environmental conclusions

Within the limitations imposed by the scope of services, the preparation of this report has been undertaken and performed in a professional manner, in accordance with generally accepted environmental consulting practices. No other warranty, whether express or implied, is made.

The advice herein relates only to this project and all results conclusions and recommendations made should be reviewed by a competent person with experience in environmental investigations, before being used for any other purpose.

Strategen-JBS&G accepts no liability for use or interpretation by any person or body other than the client who commissioned the works. This report should not be reproduced without prior approval by the client, or amended in any way without prior approval by Strategen-JBS&G, and should not be relied upon by other parties, who should make their own enquiries.

9. References

Standards Australia, Australian Standard 1940 (2017) 'The Storage and Handling of Flammable and Combustible Liquids' (AS:1940), 2017.

Office of Environmental Protection Authority (OEPA) 2012a, Post Assessment Guideline for Preparing a Compliance Assessment Plan, OEPA, Perth, August 2012.

Office of Environmental Protection Authority (OEPA) 2012b, Post Assessment Guideline for Preparing an Audit Table, OEPA, Perth, August 2012.

Office of Environmental Protection Authority (OEPA) 2012c, Post Assessment Guideline for Making Information Publicly Available, OEPA, Perth, August 2012.

Office of Environmental Protection Authority (OEPA) 2012d, Post Assessment Guideline for Preparing a Compliance Assessment Report, OEPA, Perth, August 2012.

Woodman Environmental (Woodman) 2015, Neerabup Gas Pipeline Rehabilitation Completion Review, report prepared for Newgen Neerabup Partnership, 20 October 2015.

Appendix A Statement of Compliance

Statement of Compliance

1 Proposal and Proponent Details

Proposal Title	330 MW Gas-fired Power Station, Neerabup, City of Wanneroo
Statement Number	759
Proponent Name	NewGen Neerabup Pty Ltd
Proponent's Australian Company Number (where relevant)	126 965 722


2 Statement of Compliance Details

Reporting Period	1/07/18 to 30/06/19
------------------	---------------------

Implementation phase(s) during reporting period (please tick ✓ relevant phase(s))							
Pre-construction	<input type="checkbox"/>	Construction	<input type="checkbox"/>	Operation	<input checked="" type="checkbox"/>	Decommissioning	<input type="checkbox"/>

Audit Table for Statement addressed in this Statement of Compliance is provided at Attachment:	Appendix B
<p>An audit table for the Statement addressed in this Statement of Compliance must be provided as Attachment 2 to this Statement of Compliance. The audit table must be prepared and maintained in accordance with the Department of Water and Environmental Regulation (DWER) <i>Post Assessment Guideline for Preparing an Audit Table</i>, as amended from time to time. The 'Status Column' of the audit table must accurately describe the compliance status of each implementation condition and/or procedure for the reporting period of this Statement of Compliance. The terms that may be used by the proponent in the 'Status Column' of the audit table are limited to the Compliance Status Terms listed and defined in Table 1 of Attachment 1.</p>	

Were all implementation conditions and/or procedures of the Statement complied with within the reporting period? (please tick ✓ the appropriate box)		
No (please proceed to Section 3)	<input type="checkbox"/>	Yes (please proceed to Section 4) <input checked="" type="checkbox"/>

Each page (including Attachment 2) must be initialed by the person who signs Section 4 of this Statement of Compliance. INITIALS: 

3 Details of Non-compliance(s) and/or Potential Non-compliance(s)

The information required Section 3 must be provided for each non-compliance or potential non-compliance identified during the reporting period covered by this Statement of Compliance.


Non-compliance/potential non-compliance 3-1

Which implementation condition or procedure was non-compliant or potentially non-compliant?
Was the implementation condition or procedure non-compliant or potentially non-compliant?
On what date(s) did the non-compliance or potential non-compliance occur (if applicable)?

Was this non-compliance or potential non-compliance reported to the Chief Executive Officer, DWER?	
<input type="checkbox"/> Yes <input type="checkbox"/> Reported to DWER verbally Date _____ <input type="checkbox"/> Reported to DWER in writing Date _____	<input type="checkbox"/> No

What are the details of the non-compliance or potential non-compliance and where relevant, the extent of and impacts associated with the non-compliance or potential non-compliance?
What is the precise location where the non-compliance or potential non-compliance occurred (if applicable)? (please provide this information as a map or GIS co-ordinates)
What was the cause(s) of the non-compliance or potential non-compliance?
What remedial and/or corrective action(s), if any, were taken or are proposed to be taken in response to the non-compliance or potential non-compliance?
What measures, if any, were in place to prevent the non-compliance or potential non-compliance before it occurred? What, if any, amendments have been made to those measures to prevent re-occurrence?
Please provide information/documentation collected and recorded in relation to this implementation condition or procedure: <ul style="list-style-type: none"> • in the reporting period addressed in this Statement of Compliance; and • as outlined in the approved Compliance Assessment Plan for the Statement addressed in this Statement of Compliance. (the above information may be provided as an attachment to this Statement of Compliance)

For additional non-compliance or potential non-compliance, please duplicate this page as required.

Each page (including Attachment 2) must be initialed by the person who signs Section 4 of this Statement of Compliance. INITIALS: 

4 Proponent Declaration

I, Bruno Lanciano, Station Manager, (full name and position title) declare that I am authorised on behalf of NewGen Neorabus Pty Ltd (being the person responsible for the proposal) to submit this form and that the information contained in this form is true and not misleading.

Signature: 

Date: 06/01/2020

Please note that:

- it is an offence under section 112 of the *Environmental Protection Act 1986* for a person to give or cause to be given information that to his knowledge is false or misleading in a material particular; and
- the Chief Executive Officer of the DWER has powers under section 47(2) of the *Environmental Protection Act 1986* to require reports and information about implementation of the proposal to which the statement relates and compliance with the implementation conditions.

5 Submission of Statement of Compliance

One hard copy and one electronic copy (preferably PDF on CD or thumb drive) of the Statement of Compliance are required to be submitted to the Chief Executive Officer, DWER, marked to the attention of Manager, Compliance (Ministerial Statements).

Please note, the DWER has adopted a procedure of providing written acknowledgment of receipt of all Statements of Compliance submitted by the proponent, however, the DWER does not approve Statements of Compliance.


6 Contact Information

Queries regarding Statements of Compliance, or other issues of compliance relevant to a Statement may be directed to Compliance (Ministerial Statements), DWER:

Manager, Compliance (Ministerial Statements)
 Department of Water and Environmental Regulation
 Postal Address: Locked Bag 10
 EAST PERTH WA 6892
 Phone: (08) 6145 0800
 Email: compliance@dwer.wa.gov.au

7 Post Assessment Guidelines and Forms

Post assessment documents can be found at www.epa.wa.gov.au in the following locations:

Each page (including Attachment 2) must be initialed by the person who signs Section 4 of this Statement of Compliance. INITIALS: 

ATTACHMENT 1

Table 1 Compliance Status Terms

Compliance Status Terms	Abbrev	Definition	Notes
Compliant	C	Implementation of the proposal has been carried out in accordance with the requirements of the audit element.	This term applies to audit elements with: <ul style="list-style-type: none"> ongoing requirements that have been met during the reporting period; and requirements with a finite period of application that have been met during the reporting period, but whose status has not yet been classified as 'completed'.
Completed	CLD	A requirement with a finite period of application has been satisfactorily completed.	This term may only be used where: <ul style="list-style-type: none"> audit elements have a finite period of application (e.g. construction activities, development of a document); the action has been satisfactorily completed; and the DWER has provided written acceptance of 'completed' status for the audit element.
Not required at this stage	NR	The requirements of the audit element were not triggered during the reporting period.	This should be consistent with the 'Phase' column of the audit table.
Potentially Non-compliant	PNC	Possible or likely failure to meet the requirements of the audit element.	This term may apply where during the reporting period the proponent has identified a potential non-compliance and has not yet finalized its investigations to determine whether non-compliance has occurred.
Non-compliant	NC	Implementation of the proposal has not been carried out in accordance with the requirements of the audit element.	This term applies where the requirements of the audit element are not "complete" have not been met during the reporting period.
In Process	IP	Where an audit element requires a management or monitoring plan be submitted to the DWER or another government agency for approval, that submission has been made and no further information or changes have been requested by the DWER or the other government agency and assessment by the DWER or other government agency for approval is still pending.	The term 'In Process' may not be used for any purpose other than that stated in the Definition Column. The term 'In Process' may not be used to describe the compliance status of an implementation condition and/or procedure that requires implementation throughout the life of the project (e.g. implementation of a management plan).

Each page (including Attachment 2) must be initialed by the person who signs Section 4 of this Statement of Compliance. INITIALS: 

Appendix B MS 759 audit table

Table B.1: Compliance with MS 759

Audit code Subject	Action How Objective Criteria	Phase	When/Where	Evidence	Comments	Status
759:M1.1 Implementation	<u>Action</u> Implement the proposal as documented and described in schedules 1 and 2 of Statement 759 subject to the conditions and procedures of this statement. <u>Objective</u> To avoid unforeseen or unassessed impacts.	Overall.		Refer to Appendix C. Refer to 759:M10.1.	Refer to Appendix C of this audit report which outlines compliance with Schedule 1. Refer to 759:M10.1 which addresses compliance with Schedule 2, which is considered completed.	Compliant
759:M2.1 Nominated proponent	<u>Action</u> The proponent for the time being nominated by the Minister for the Environment under sections 38(6) or 38(7) of the <i>Environmental Protection Act 1986</i> is responsible for the implementation of the proposal. <u>Objective</u> To ensure legal responsibility rests with the nominated proponent.	Overall.		Management advice 30 October 2019.	NewGen Neerabup Partnership is still the proponent for the proposal.	Compliant
759:M2.2 Proponent nomination	<u>Action</u> Notify the Chief Executive Officer of the DEC (CEO) of any change of the name and address for the serving of notices or other correspondence within 30 days of such change. <u>How</u> Written notification. <u>Objective</u> To enable the DEC to maintain contact with the proponent.	Overall.	Within 30 days of change of contact details.	Management advice 30 October 2019.	The contact name and address did not change during the audit period.	Compliant
759:M3.1 Commencement	<u>Action</u> The authorisation to implement the proposal provided for in Ministerial Statement 759 shall lapse and be void within five years after the date of this statement if the proposal to which this statement relates is not substantially commenced. <u>How</u> Commence substantial construction. <u>Objective</u> To define the period for which the authorisation to implement is valid.	Overall.	Prior to 21 January 2013.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M3.2 Commencement	<u>Action</u> Provide the CEO with written evidence which demonstrates that the proposal has substantially commenced on or before the 21 January 2013. <u>How</u> Written evidence. <u>Objectives</u> To ensure the CEO is notified that the project has substantially commenced.	Overall.	Prior to 21 January 2013.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M4.1 Compliance reporting	<u>Action</u> Submit to the CEO environmental compliance reports annually reporting on the previous twelve-month period, unless required by the CEO to report more frequently. <u>How</u> Written evidence addressing each element of the audit table. <u>Objective</u> To provide evidence that the proposal is being implemented as approved and that the relevant conditions and commitments are being met.	Overall.	Annually unless required by the CEO to report more frequently.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018 C_001_ERM Power_190814 2018-2019 NNP DWER Annual Monitoring & Compliance Report Submission email – 2_14082019 C_005_ERM Power_Annual Compliance Audit Report for the July 2017-June 2018 period_20122019	The 2018 Compliance Assessment Report (CAR) addressed the audit period from June 2017 to July 2018 and was submitted to DWER ERM Power submitted the 2018 Compliance Assessment Report to the DWER on 19 December 2019.	Compliant
759:M4.2 Compliance Reporting - Audit Program	<u>Action</u> Prepare and submit an Audit Program in a format acceptable to the CEO.	Design.		R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M4.3 Compliance reporting	<u>Action</u> Submit compliance reports to CEO. <u>How</u> Environmental compliance reports shall:	Overall.	Annually, unless required by the CEO to report more frequently.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018 C_005_ERM Power_Annual Compliance Audit Report for the July 2017-June 2018 period_20122019	The 2018 Compliance Assessment Report was submitted to the DWER on 19 December 2019. NB: In terms of auditing key management actions within relevant management plans or programs; the RMP, SEMP and GGAP are relevant. Only key actions from these plans were audited during	Compliant

Audit code Subject	Action How Objective Criteria	Phase	When/Where	Evidence	Comments	Status
	<ol style="list-style-type: none"> 1. Be endorsed by signature of the proponent's CEO or a person, approved in writing by the CEO, delegated to sign on behalf of the proponent's CEO. 2. State whether the proponent has complied with each condition and procedure contained in Statement 759. 3. Provide verifiable evidence of compliance with each condition and procedure contained in Statement 759. 4. State whether the proponent has complied with each key action contained in any environmental management plan or program required by Statement 759. 5. Provide verifiable evidence of conformance with each key action contained in any environmental management plan or program required by Statement 759. 6. Identify all non-compliances and non-conformances and describe the corrective and preventative actions taken in relation to each non-compliance or non-conformance. 7. Review the effectiveness of all corrective and preventative actions taken. 8. Describe the state of implementation of the proposal. <p><u>Objective</u> To provide evidence that the proposal is being implemented as approved, and that the relevant conditions and commitments are being met.</p>				<p>this audit period (see Appendix D and Appendix E). Actions in the RMP have been deemed completed.</p> <p>In addition, actions identified in the licence to operate (L8356/2009/2) and groundwater licence (GWL164093(3)) have been assessed as part of the Banker's Audit (Appendix F).</p>	
759:M4.4 Compliance reporting – public availability	<p><u>Action</u> Compliance reports shall be made publicly available in a manner approved by the CEO.</p> <p><u>How</u> Carry out the following:</p> <ol style="list-style-type: none"> 1. Advertise the availability of the document in the 'Public Notices Section' of the local community newspaper. 2. Provide copies of the documentation to the DEC library (1 hard copy, 1 CD copy), local government public library (2 copies), JS Battye library (2 copies). 3. Post the document on the proponent's website. <p><u>Objective</u> To ensure that the public is kept informed.</p>	Overall.		<p>Site inspection 30 October 2019.</p> <p>G_001_Website screenshot of CAR_14112019</p> <p>R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018</p> <p>https://ermpower.com.au/wp-content/uploads/2018/12/2017-2018-Neerabup-Environmental-Compliance-Report.pdf</p>	<p>The 2018 Compliance Assessment Report is available on the ERM Power website.</p> <p>Previous Compliance Assessment Reports state that OEPA (now DWER) accepts publication of documents on a website as publicly available and meeting the objective of ensuring the public is kept informed.</p>	Compliant
759:M5.1 Performance review	<p><u>Action</u> Submit a Performance Review Report to the EPA every five years from the start of production.</p> <p><u>How</u> The Performance Review Report shall address:</p> <ol style="list-style-type: none"> 1. The major environmental issues associated with implementing the project; the environmental objectives for those issues; the methodologies used to achieve these; and the key indicators of environmental performance measured against those objectives. 2. The level of progress in the achievement of sound environmental performance, including industry benchmarking, and the use of best available technology where practicable. 3. Significant improvements gained in environmental management, including the use of external peer reviews. 4. Stakeholder and community consultation about environmental performance and the outcomes of that consultation, including a report of any on-going concerns being expressed. 5. The proposed environmental objectives over the next five years, including improvements in technology and management processes. <p><u>Objective</u> To provide evidence of environmental performance and to identify aspects that may require environmental improvements.</p>	Overall.	Every 5 years from the start of production. 5 years from 3 December 2009.	R_002_Strategen-JBS&G_2013-2014-Neerabup-Environmental-Compliance-Report-1_16122014	<p>Operation of the power station commenced in December 2009. The first Performance Review Report was submitted to the OEPA as part of the 2013-2014 Compliance Assessment Report (R_002). The next Performance Review Report is due to be submitted as part of this Compliance Assessment Report (refer to section 6).</p>	Compliant
759:M5.2 Performance review – public availability	<p><u>Action</u> Performance Review reports shall be made publicly available in a manner approved by the CEO.</p> <p><u>How</u> Carry out the following:</p> <ol style="list-style-type: none"> 1. Advertise the availability of the document in the 'Public Notices Section' of the local community newspaper. 	Overall.	Every 5 years after the start of construction. 5 years from 3 December 2009.	<p>G_001_Website screenshot of CAR_14112019</p> <p>https://www.ermpower.com.au/wp-content/uploads/2017/11/2013-2014-Neerabup-Environmental-Compliance-Report-1.pdf</p>	<p>As outlined for 759:M5.1, the first Performance Review was submitted to the OEPA as part of the 2013-2014 Compliance Assessment Report.</p> <p>The 2013-14 Compliance Assessment Report - which contains the 5 year performance review is available on the ERM Power website.</p>	Compliant

Audit code Subject	Action How Objective Criteria	Phase	When/Where	Evidence	Comments	Status
	2. Provide copies of the documentation to the DEC library (1 hard copy, 1 CD copy), local government public library (2 copies), JS Battye library (2 copies). 3. Post the document on the proponent's website. <u>Objectives</u> To ensure that the public is kept informed.					
759:M6.1 Vegetation disturbance – boundaries	<u>Action</u> Prior to ground disturbing activities, clearly delineate on the ground the boundaries of the gas pipeline lateral and electricity transmission line easements and the area of disturbance outside the easements. <u>How</u> Boundaries are to be clearly visible for workers conducting disturbance activities. <u>Objectives</u> To ensure no disturbance occurs to vegetation outside the boundaries.	Design and construction.	Prior to ground-disturbing activities.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M6.2 Vegetation disturbance – exceedance of boundaries	<u>Action</u> Do not cause disturbance of vegetation outside the delineated gas pipeline lateral and electricity line easements, or the delineated area of disturbance outside the easements referred to in condition 6–1, unless authorised by the Minister for the Environment. <u>How</u> Clearing to only be within delineated areas. <u>Objective</u> To ensure no disturbance of vegetation outside the delineated boundaries.	Overall.		R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M6.3 Vegetation disturbance – environmentally sensitive areas	<u>Action</u> Do not cause or allow disturbance of vegetation outside a 20-metre wide gas pipeline lateral easement in environmentally sensitive areas, unless authorised by the Minister for the Environment. <u>How</u> Delineated areas within environmentally sensitive areas to be limited to a 20 m wide easement unless otherwise authorised by the Minister for the Environment. <u>Objective</u> To ensure no additional disturbance of vegetation occurs outside approved boundaries in environmentally sensitive areas.	Construction.	Within environmentally sensitive areas.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M7.1 Rehabilitation - Management Plan	<u>Action</u> Prior to ground disturbing activities prepare a Rehabilitation Management Plan in consultation with DEC, to the requirements of the Minister for Environment on advice of the EPA. <u>How</u> The Rehabilitation Management Plan shall address: 1. Weed management protocols. 2. Dieback management protocols. 3. Soil management protocols. 4. Rehabilitation completion criteria. 5. The need for propagule augmentation to achieve completion criteria. 6. With reference to, EPA Guidance Statement No. 6 - Rehabilitation of Terrestrial Ecosystems. <u>Objective</u> To ensure rehabilitation meets EPA requirements.	Design.	Prior to ground-disturbing activities.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M7.2 Rehabilitation – management period	<u>Action</u> Manage rehabilitation of the gas pipeline lateral and electricity transmission line easements until the rehabilitation completion criteria, referred to in condition 7-1, have been achieved. (Note: obligations under DoIR legislation mean the vehicular access track must be maintained and thus certain completion criteria may not be achievable within the access track). <u>How</u> In accordance with industry best practice environmental management and rehabilitation plan. Criteria established by M7.1 and EPA Guidance Statement No. 6 - Rehabilitation of Terrestrial Ecosystems.	Overall.		R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed

Audit code Subject	Action How Objective Criteria	Phase	When/Where	Evidence	Comments	Status
	<u>Objective</u> To ensure rehabilitation meets EPA requirements.					
759:M7.3 Rehabilitation Management Plan – review and revision	<u>Action</u> As required, review and revise the Rehabilitation Management Plan in consultation with DEC. <u>How</u> With reference to EPA Guidance Statement No. 6 – Rehabilitation of Terrestrial Ecosystems. <u>Objective</u> To ensure rehabilitation meets DEC and EPA requirements.	Overall.		R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M7.4 Rehabilitation Management Plan – implementation	<u>Action</u> Implement the Rehabilitation Management Plan required by M7.1 and subsequent revisions of the Rehabilitation Management Plan as required by M7.3. <u>Objective</u> To ensure rehabilitation planning and activities are implemented.	Overall.		R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M7.5 Rehabilitation Management Plan – public availability	<u>Action</u> The Rehabilitation Management Plan and subsequent revisions shall be made publicly available in a manner approved by the CEO. <u>How</u> Carry out the following (according to the recently approved Audit Program): 1. Advertise the availability of the document in the ‘Public Notices Section’ of the local community newspaper. 2. Provide copies of the documentation to the DEC library (1 hard copy, 1 CD copy), local government public library (2 copies), JS Battye library (2 copies). 3. Post the document on the proponent’s website. <u>Objective</u> To ensure the public is kept informed.	Overall.	After approval of the Plan by Minister for Environment.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M8.1:1 Fauna – trench clearing	<u>Action</u> Trapped fauna within open trenches shall be cleared and recorded by a suitably trained fauna-clearing person no later than three hours after sunrise. The clearing and recording shall be repeated before sunset. (Note: “Fauna-clearing person” means an employee of the proponent whose responsibility it is to walk the open trench to recover and record fauna found within the trench.) <u>How</u> Employ a suitably trained fauna management person. <u>Objective</u> To minimise death or injury to fauna trapped in the open trenches.	Construction.	No later than three hours after sunrise and again before sunset.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759 M8.1:2 Fauna – trench clearing	<u>Action</u> Open trenches shall be cleared and recorded by a suitably trained fauna-clearing person no more than one hour prior to backfilling of trenches. <u>How</u> Implement Fauna Management Plan/Protocol. <u>Objective</u> To minimise death or injury to fauna trapped in open trenches.	Construction.	No more than one hour before backfilling of trenches.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759 M8.2 Fauna clearing – qualifications of fauna clearing person	<u>Action</u> The fauna-clearing person shall be experienced to the requirements of the DEC. <u>How</u> The fauna-clearing person will be experienced to the requirements of the DEC in: 1. Fauna identification, capture and handling (including venomous snakes). 2. Identification of tracks, scats, burrows and nests of conservation significant species. 3. Fauna vouchering. 4. Assessing injured fauna for suitability for release, rehabilitation or euthanasia. 5. Familiarity with the ecology of the species which may be encountered in order to be able to appropriately translocate fauna encountered. 6. Performing euthanasia. <u>Objective</u> To ensure fauna handling and assessment is of a high standard.	Construction.	Prior to trench construction and fauna handling.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed

Audit code Subject	Action How Objective Criteria	Phase	When/Where	Evidence	Comments	Status
759:M8.3 Fauna – clearing person training	<p><u>Action</u> Ensure that basic fauna handling training is provided to fauna clearing persons who do not possess the skills and experience outlined in M8-2 prior to the fauna-clearing person commencing employment.</p> <p><u>How</u> Fauna handling training course delivered to inexperienced staff.</p> <p><u>Objective</u> To ensure fauna handling and assessment is of a high standard.</p>	Design.	Prior to trench construction and fauna handling by inexperienced persons.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M8.4 Fauna – clearing person training	<p><u>Action</u> Fauna handling training as outlined in M8.3 shall be developed in consultation with the DEC.</p> <p><u>How</u> In consultation with DEC.</p> <p><u>Objective</u> To ensure best practice fauna handling and assessment.</p>	Design.	Prior to fauna handling by inexperienced persons.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M8.5 Fauna – open trench length	<p><u>Action</u> Open trench lengths shall not exceed a length capable of being inspected and cleared by fauna clearing persons within the required times as set out in condition 8.1.</p> <p><u>Objective</u> To minimise death or injury to fauna trapped in the open trenches.</p>	Construction.	In areas where there are open trenches.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M8.6 Fauna – flooding of trench	<p><u>Action</u> Monitor weather forecasts through the Bureau of Meteorology and in the event of a weather forecast indicating rainfall sufficient to cause flooding of trenches or drowning of fauna trapped in trenches, in consultation with DEC, backfill all lengths of open trench with a potential to be flooded or cause drowning of fauna.</p> <p><u>How</u> Monitor weather forecasts in areas where there are open trenches. Calculate rainfall level which could cause flooding of trenches or drowning of fauna. Consult with DEC where weather indicates potential flooding or drowning of fauna could occur as to whether backfilling of trenches needs to occur.</p> <p><u>Objective</u> To minimise harm to fauna trapped in open trenches.</p>	Construction.	In areas where there are open trenches.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759 M8.7:1 Fauna management – report	<p><u>Action</u> Produce a report on fauna management within the gas pipeline lateral easement at the completion of gas pipeline construction and provide report to the CEO no later than 14 days after the completion of the gas pipeline construction.</p> <p><u>How</u> The Fauna Management Report shall include: 1. Details of all fauna inspections. 2. The number of fauna cleared from trenches. 3. Fauna interactions. 4. Fauna mortalities. 5. All actions taken.</p> <p><u>Objective</u> To ensure that fauna management was carried out in accordance with conditions and, to understand project impacts on fauna and to further develop industry best practice fauna management.</p>	Post-construction.	Provided to CEO no later than 14 days after the completion of gas pipeline construction.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759 M8.7:2 Fauna management report - publicly availability	<p><u>Action</u> Report on fauna management to be made publicly available in a manner approved by the CEO.</p> <p><u>How</u> Carry out the following (according to the recently approved Audit Program): 1. Advertise the availability of the document in the 'Public Notices Section' of the local community newspaper. 2. Provide copies of the documentation to the DEC library (1 hard copy, 1 CD copy), local government public library (2 copies), JS Battye library (2 copies). 3. Post the document on the proponent's website.</p> <p><u>Objective</u> To ensure the public is informed of project impacts on fauna.</p>	Post-construction.	No later than 14 days after the completion of gas pipeline construction.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed

Audit code Subject	Action How Objective Criteria	Phase	When/Where	Evidence	Comments	Status
759 M9.1 Stack Emissions Report	<p><u>Action</u> Prior to submission of a works approval application, provide a report to the CEO for approval.</p> <p><u>How</u> The report shall:</p> <ol style="list-style-type: none"> 1. Confirm the engineering design details for the emission of gaseous and particulate pollutants, including stack heights, stack parameters, exit temperatures and exit velocities; and 2. Estimate the concentration of nitrogen oxides and other gaseous and particulate pollutants, under normal and worst-case conditions, including start-up and upset emissions. <p><u>Objective</u> To ensure that best available practicable and efficient technologies are being used and that stack emissions can be managed to below required environmental levels.</p> <p><u>Criteria</u> With reference to the DEC Continuous Emission Monitoring System (CEMS) Code for Stationary Source Air Emissions.</p>	Design.	Prior to submitting a works approval application.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759 M9.2 Stack emissions Management Plan	<p><u>Action</u> Prepare a Stack Emissions Management Plan to the requirements of the Minister for Environment at least three months prior to commencement of operations.</p> <p><u>How</u> The Stack Emissions Management Plan shall include:</p> <ol style="list-style-type: none"> 1. Proposed targets and standards. 2. A stack emissions monitoring programme, which includes nitrogen oxides and other gaseous and particulate pollutants. 3. Annual reporting. <p><u>Objective</u> To ensure that best available practicable and efficient technologies are used to minimise and monitor air emissions from the power station.</p> <p><u>Criteria</u> With reference to the DEC Continuous Emission Monitoring System (CEMS) Code for Stationary Source Air Emissions.</p>	Design.	At least three months prior to commencement of operations.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759 M9.3 Stack Emissions Management Plan – implementation	<p><u>Action</u> Implement the Stack Emissions Management Plan required by condition 9.2.</p> <p><u>Objective</u> To ensure that best available practicable and efficient technologies are used to minimise and monitor air emissions from the power station.</p>	Design.		Refer to Appendix D R_003_ERM Power_2018-2019-SEMP-Annual-Compliance-Report_10122019	<p>The approved updated SEMP (Rev 2.0) is being implemented (see Appendix D). No modifications were made to the plan during this audit period.</p> <p>The SEMP annual compliance report indicates that monitoring for all parameters outlined in Appendix D was undertaken for unit 11 and unit 12 on 7 January 2019.</p> <p>Of the five key actions, four were conformant and one was complete.</p>	Compliant
759 M9.4 Stack Emissions Management Plan –publicly available	<p><u>Action</u> The Stack Emissions Management Plan required by condition 9.2 shall be made publicly available in a manner approved by the CEO.</p> <p><u>How</u> Carry out the following (according to the recently approved Audit Program):</p> <ol style="list-style-type: none"> 1. Advertise the availability of the document in the 'Public Notices Section' of the local community newspaper. 2. Provide copies of the documentation to the DEC library (1 hard copy, 1 CD copy), local government public library (2 copies), JS Battye library (2 copies). 3. Post the document on the proponent's website. <p><u>Objective</u> To ensure the public is kept informed.</p>	Design.	Prior to commencement of operations.	G_001_Website Screenshot of Regulatory Reports_14112019 https://ermpower.com.au/wp-content/uploads/2018/10/2017-2018-SEMP-Annual-Compliance-Report.pdf	The SEMP is made publicly available on the ERM Power website, consistent with OEPA requirements for making documents available to the public. The updated SEMP is available on the ERM Power website.	Compliant
759 M10.1 Greenhouse Gas Abatement Programme – prepare	<p><u>Action</u> Prior to commencement of ground disturbing activities, prepare and submit a Greenhouse Gas Abatement Programme for approval by CEO.</p> <p><u>How</u> The Greenhouse Gas Abatement Programme shall set out measures and processes to:</p>	Design.	Prior to commencement of ground disturbing activities.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed

Audit code Subject	Action How Objective Criteria	Phase	When/Where	Evidence	Comments	Status
	1. Ensure that the plant is designed and operated in a manner which achieves reductions in “greenhouse gas” emissions as far as practicable. 2. Provide for ongoing “greenhouse gas” emissions reductions over time. 3. Ensure that the total net “greenhouse gas” emissions and/or “greenhouse gas” emissions per unit of product from the project are minimised; and 4. Manage “greenhouse gas” emissions in accordance with the Framework Convention on Climate Change 1992, and consistent with the contemporary National Greenhouse Strategy as updated from time to time. <u>Objective</u> To manage greenhouse gas emissions to achieve ongoing reductions and minimise project emissions. <u>Criteria</u> Criteria set out in Schedule 2 of Statement 759 and on advice from the EPA. With reference to EPA Guidance Statement No. 12, Minimising Greenhouse Gas Emissions.					
759 M10.2 Greenhouse Gas Abatement Programme – implementation	<u>Action</u> Implement the Greenhouse Gas Abatement Programme unless modifications are approved by the CEO. <u>Objective</u> To manage greenhouse gas emissions to achieve ongoing reductions and minimise project emissions.	Overall.	Prior to commencement of ground disturbing activities.	Refer to Appendix E Management advice 30 October 2019. Site inspection 30 October 2019.	The GGAP is being implemented (see Appendix E). No modifications have been made to the plan during the audit period. Of the seven key actions, five were conformant and two were complete.	Compliant
759 M10.3 Greenhouse Gas Abatement Programme – publicly available	<u>Action</u> Prior to commencement of ground disturbing activities, the Greenhouse Gas Abatement Programme required by condition 10.1 shall be made publicly available in a manner approved by the CEO. <u>How</u> Carry out the following (according to the recently approved Audit Program): 1. Advertise the availability of the document in the ‘Public Notices Section’ of the local community newspaper. 2. Provide copies of the documentation to the DEC library (1 hard copy, 1 CD copy), local government public library (2 copies), JS Battye library (2 copies). 3. Post the document on the proponent’s website. <u>Objective</u> To ensure the public is kept informed.	Design.	Prior to commencement of ground disturbing activities.	G_001_Website Screenshot of Regulatory Report_14112019 https://ermpower.com.au/wp-content/uploads/2013/08/Neerabup-Greenhouse-Gas-Abatement-Programme-1.pdf	The GGAP is made publicly available on the ERM Power website, consistent with DWER requirements for making documents regarding the proposal publicly available. The GGAP was available on the ERM Power website at the time of the audit.	Compliant
759:M11.1 Preliminary Decommissioning Plan – prepare	<u>Action</u> Prior to commencement of ground disturbing activities, prepare a Preliminary Decommissioning Plan for approval by the CEO. <u>How</u> The Plan shall describe the framework and strategies to ensure that the site is suitable for future land uses, and provides: 1. The rationale for the siting and design of plant and infrastructure as relevant to environmental protection. 2. A conceptual description of the final landform at closure. 3. A plan for a care and maintenance phase. 4. Initial plans for the management of noxious materials. <u>Objective</u> To appropriately decommission the NewGen Neerabup 330 MW Gas Fired Power Station, Gas Pipeline and High Voltage Transmission Line in accordance with regulatory requirements and accepted best practice environmental management.	Design.	Prior to commencement of ground-disturbing activities.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
759:M11.2 Final Decommissioning Plan – prepare and submit	<u>Action</u> At least six months prior to the anticipated date of closure, or at a time approved by the EPA, submit a Final Decommissioning Plan designed to ensure that the site is suitable for future land uses for approval by the CEO. <u>How</u> The Final Decommissioning Plan shall set out procedures and measures for: 1. Removal or, if appropriate, retention of plant and infrastructure agreed in consultation with relevant stakeholders. 2. Rehabilitation of all disturbed areas to a standard suitable for the agreed new land use(s).	Operation and Closure.	At least 6 months prior to anticipated closure.	Management advice 30 October 2019. Site inspection 30 October 2019.	The project life is approximately 30 years, with closure anticipated to occur in 2040.	Not required at this stage

Audit code Subject	Action How Objective Criteria	Phase	When/Where	Evidence	Comments	Status
	3. Identification of contaminated area, including provision of evidence of notification and proposed management measures to relevant statutory authorities. <u>Objective</u> To ensure that the site is left in an environmentally acceptable condition suitable for future land uses.					
759:M11.3 Final Decommissioning Plan – implementation	<u>Action</u> Implement the Final Decommissioning Plan until such time as the Minister for the Environment determines, on advice of the CEO, that decommissioning responsibilities have been fulfilled. <u>Objective</u> To ensure that the Final Decommissioning Plan is implemented.	Closure.	Until such time as the Minister determines that decommissioning responsibilities have been fulfilled.	Refer to 759:M11.2	Refer to 759:M11.2	Not required at this stage
759:M11.4 Final Decommissioning Plan – public availability	<u>Action</u> The Final Decommissioning Plan shall be made publicly available in a manner approved by the CEO. <u>How</u> Carry out the following: 1. Advertise the availability of the document in the ‘Public Notices Section’ of the local community newspaper. 2. Provide copies of the documentation to the DEC library (1 hard copy, 1 CD copy), local government public library (2 copies), JS Battye library (2 copies). 3. Post the document on the proponent’s website. <u>Objective</u> To ensure the public is kept informed.	Overall.	After approval of Plan by CEO, and prior to implementation of Plan.	Refer to 759:M11.2	Refer to 759:M11.2	Not required at this stage

Appendix C MS 759 Schedule 1 audit table

Table C.1: Schedule 1 of MS 759 audit table

Element	Description	Evidence	Comments	Status
Project purpose:	To construct, operate and maintain a 330 MW power station and associated infrastructure.	Management advice 30 October 2019. Site inspection 30 October 2019. R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	Previous Compliance Assessment Reports noted that construction of the gas pipeline, transmission line and power station was completed in 2009. The power station was commissioned in December 2009, with operation and maintenance currently occurring. The operator advised that no changes have been made to the construction of the power station during the audit period and the auditors observed that this was the case.	Compliant
Project life:	30 years.	N/A.	No change, closure is anticipated to occur in 2040.	Not required at this stage
Power output:	330 MW (nominal).	Management advice 30 October 2019. R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	There have been no changes to the nominal power output for the power station. The operator advises that 330 MW is the default rating and represents a nominal rating. The station can produce 342 MW with additional controls as a maximum in peaking situations.	Compliant
Sent out electricity:	Approximately 867GWh/yr.	D_001_ERM Power_2018-2019_Schedule 1 calcs_Audit Info Neerabup Stats_Compliance_2019	Data for the 2018/19 financial year shows that sent out electricity was 185.25 GWh/yr.	Compliant
Thermal efficiency:	33.3% HHV at 25°C and 60% relative humidity.	Management advice 30 October 2019. D_001_ERM Power_2018-2019_Schedule 1 calcs_Audit Info Neerabup Stats_Compliance_2019	The operator configured the Supervisory Control and Data Acquisition (SCADA) system during July 2015 to provide real-time monitoring of thermal efficiency. These monitoring results provide more accurate calculation of thermal efficiency recorded during operation. Results from real-time monitoring recorded generator efficiency at approximately 29.83% at maximum power output from the generators.	Compliant
Plant operation:	Intermittent operation to suit demand – peak and shoulder periods.	Management advice 30 October 2019.	The operator advised that intermittent demand is so far associated with and limited to very hot or very cold days, low occurrences of other participant significant outages, low probability of high market prices and limited grid feeds (generation nomination) as requested by Synergy.	Compliant
Operating hours:	Approximately 2628 hours per year.	D_001_ERM Power_2019-2019_Schedule 1 calcs_Audit Info Neerabup Stats_Compliance_2019	The operating hours for the two units combined was 1,084 hours during the audit period.	Compliant
Capacity factor:	Approximately 30%.	R_004_ERM Power_2018-2019 NewGen Neerabup DWER Annual Compliance Monitoring & Compliance Report_07082019	Based upon 330.6 MW capacity, the capacity factor was 6.18% during the audit period.	Compliant
Power station footprint:	Site is 10 ha of cleared farming land of which approximately 4 ha is used for infrastructure.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
Pipeline footprint:	Construction corridor 30 m wide over 30 km length. Approximately 30 ha of native vegetation to be cleared and rehabilitated after construction.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
Transmission line footprint:	Approximately 400 m ² of native vegetation for construction of each of seven single column power pole bases.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
Fuel:				
• Type:	Natural gas.	Management advice 30 October 2019.	Natural gas is delivered from the Dampier to Bunbury Natural Gas Pipeline (DBNGP) to lateral that serves the station.	Compliant
• Source:	North-west Shelf.	Management advice 30 October 2019.	The supply of gas provided through the DBNGP is sourced from the North West Shelf, and supplemented from other gas fields en-route, and is controlled by the pipeline owner/operator (DBP).	Compliant
• Method of transport:	Dampier to Bunbury Natural Gas Pipeline and an approximately 30 km long gas pipeline lateral to the power station site.	Management advice 30 October 2019. Site inspection 30 October 2019.	Gas is delivered from DBNGP to lateral that serves the station. Auditors observed the gas yard and pipeline junction that services the power station.	Compliant
Major plant components				
Power station gas turbines:	Two 165 MW open-cycle gas turbines fitted with low NOx burners.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
Number of stacks:	2.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
Height of stacks:	35 m.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed

Element	Description	Evidence	Comments	Status
Stack diameter:	6 m.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
Gas pipeline:	A dedicated lateral from the Dampier to Bunbury Natural Gas Pipeline of approximately 30 km length.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
Compressor station:	Located on gas pipeline lateral and consists of two compressor units with only one unit in operation at any time.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
Electricity transmission line:	330 kV line to Western Power Neerabup terminal substation – approximately 2 km long.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 CAR.	Completed
Inputs				
Natural gas:	Approximately 11.2 PJ per year.	D_001_ERM Power_2018-2019_Schedule 1 calcs_Audit Info Neerabup Stats_Compliance_2019	A total of 2.22 PJ of natural gas per year was utilised during the audit period.	Compliant
Process water:	Approximately 15 ML per year from onsite bore.	R_006_ERM Power_2018 2019 Bore 1 End of year online readings_29062019 R_007_ERM Power_2018 2019 Bore 2 End of year online readings_29062019 D_001_ERM Power_2018-2019_Schedule 1 calcs_Audit Info Neerabup Stats_Compliance_2019	Two bores are utilised on-site with a total water use of 8.51 ML used in the audit period: Bore 1 of 2: 4,607 kL/year. Bore 2 of 2: 3,904 kL/year.	Compliant
Outputs				
Wastewater:	No discharge of wastewater.	Management advice 30 October 2019. Site inspection 30 October 2019.	There was no discharge of wastewater. The Reverse Osmosis plant minimises waste water collected in the evaporation ponds.	Compliant
Oxides of nitrogen (NOx):	380,000kg/yr (<25 ppmv @ 15% O ₂).	R_004_ERM Power_2018-2019 NewGen Neerabup DWER Annual Monitoring & Compliance Report_07082019 R_005_NPI_WA1204 Emission Report 2018-2019_12112019	Unit 11 was recorded at 18 ppmv and Unit 12 at 10 ppmv, which is below the limit specified. Using NPI techniques it is estimated that NOx emissions were 68,153.25 kg/yr.	Compliant
Particulates (PM10):	74,000kg/yr.	D_001_ERM Power_2018-2019_Schedule 1 calcs_Audit Info Neerabup Stats_Compliance_2019	PM10 was not included in stack testing. Using NPI techniques it is estimated that PM10 emissions were 6,229.79 kg/yr.	Compliant
Carbon monoxide (CO):	93,000kg/yr (<10 ppmv @ 15% O ₂).	R_008_2017-2018 NewGen Neerabup DWER Annual Monitoring & Compliance Report. D_001_ERM Power_2018-2019_Schedule 1 calcs_Audit Info Neerabup Stats_Compliance_2019	Unit 11 was recorded at <2 ppmv and Unit 12 at <2 ppmv, which is below the limit specified. Using NPI techniques it is estimated that CO emissions were 14,529.47 kg/yr.	Compliant
Sulphur dioxide (SO ₂):	5,100 kg/yr.	Management advice 30 October 2019.	NA - Not tested for in the 2017-2018 stack test program, DER licence does not require this to be tested.	N/A
Direct greenhouse gas emissions:	Approximately 590,000 tonnes of CO ₂ -e per year.	R_009_Clean Energy Regulator_NGERS S19 REPORT FY1819_08102019	The direct greenhouse gas emissions were approximately 112,916 tonnes of CO ₂ -e for the audit period.	Compliant
Full fuel cycle greenhouse gas emissions:	Approximately 673,000 tonnes of CO ₂ -e per year.	R_009_Clean Energy Regulator_NGERS S19 REPORT_FY1819_08102019	The full fuel cycle greenhouse gas emissions were approximately 115,836 tonnes of CO ₂ -e for the audit period.	Compliant
Greenhouse intensity:	Approximately 554kg of CO ₂ -e per MWh.	Management advice 30 October 2019. D_001_ERM Power_2018-2019_Schedule 1 calcs_Audit Info Neerabup Stats_Compliance_2019	The greenhouse intensity recorded during the audit period was 615.90 kg of CO ₂ -e per MWh for the audit period which is within 11% of the 554 kg of CO ₂ -e per MWh. As reported last year, the Proponent has advised that typical operations through the reporting period involved infrequent very short duration runs (station capacity factor of 6.17 %, total of approximately 200 starts between the two units during the audit period). Management advised that the proportion of time that Neerabup power station is 'online' is very low and tends to unfavourably skew the greenhouse intensity data per output due to the inherent inefficiency of the fast start-up cycle and short runs associated with a peak demand power station. The Proponent also notes that the heat rate degrades when the station is run at lower power output and the Proponent gets requests from the market to run at lower than maximum capacity	Compliant

Element	Description	Evidence	Comments	Status
Noise:	Will comply with the Environmental Protection (Noise) Regulations 1997: <ul style="list-style-type: none"> • <30dB(A) at nearest residential property and • <65dB(A) at nearest industrial property. 	Management advice 30 October 2019. D_003_ERM Power_NPS-REG-EXT-COMP External Complaints Register_19072019	output. As the future capacity factor of the power station increases, the ratio of starts to 'online' hours should improve with a corresponding reduction in greenhouse intensity. No complaints were received during the audit period indicating that noise limits were within the required parameters.	Compliant

Appendix D Stack Emissions Management Plan Rev 2.0 (20 June 2013) audit table

Table D.1: Stack Emissions Management Plan Rev 2.0 (20 June 2013) audit table

Audit code	Action	Evidence	Comments	Status
SEMP1	The power station shall be designed and constructed to comply with the emission concentration targets specified in 5.1 (NO _x – 25 ppmv; CO – 10 ppmv). The power station will utilise low NO _x burners to ensure that emissions of oxides of nitrogen are minimised as far as is practicable.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was assessed as Completed in the 2018 ACR.	Completed
SEMP2	The power station shall be maintained and operated in a proper and efficient manner and in accordance with the manufacturer's operation and maintenance manual to ensure compliance is achieved with the emission concentration targets specified in 5.1.	Management advice 30 October 2019. D_002_ERM Power_Neerabup Inspection Plan 2009-2032_11052019	The proponent advised that the trigger item of number of starts is tracked within Neerabup Forecasted Inspection Plan 2009–2032, to indicate the appropriate timing of maintenance activities. The most recent minor inspection, the second since operations began at the plant, occurred on the 10 and 7 of November 2017. At this time Unit 11 had accumulated 250 starts and unit 12 accumulated 251 starts between the 1st to the 2nd minor inspection (within OEM tolerance). The number of starts recorded since the first minor inspection in 2014 is in accordance with the projected number of starts outlined in the Neerabup Forecasted Inspection Plan 2009–2032. The Neerabup Forecasted Inspection Plan 2009–2032 indicates that the next minor inspections are scheduled for April 2020- October 2020. As outlined in SEMP 1 above, the specified emission concentration targets are being achieved.	Compliant
SEMP3	Sampling and analysis of air pollutants, specified in Table 4 below, shall be undertaken and reported as provided by Section 4.2 of Australian Standard AS4323.1. The following list summarises the parameter and frequency of monitoring required by Table 4: <ul style="list-style-type: none"> oxides of nitrogen (mg/m³) – annually carbon monoxide (mg/m³) – annually velocity, temperature and volumetric flow rate (m/s, °C, m³/s) - annually moisture content (%) - annually dry gas density, molecular weight (kg/m³, g/gmol) - annually oxygen (%) - annually. 	R_003_ERM Power_2018-2019-SEMP-Annual-Compliance Report_10122019	The SEMP annual compliance report indicates that monitoring for all parameters outlined in Table 4 were undertaken for both Unit 11 and Unit 12 on 7 January 2019. Sampling and analysis of air pollutants are undertaken and reported in accordance with section 4.2 of Australian Standard AS4323.1.	Compliant
SEMP4	A complaints procedure shall be established to receive complaints from the community associated with air emissions from the power station. The power station operator shall investigate all complaints and, where the power station is found to be the cause of the incident, the operator shall take actions to ensure that the cause is rectified and implement measures to ensure that there is minimal risk of the incident recurring.	Management advice 30 October 2019. D_003_ERM Power_NPS_REG-EXT-COMP External Complaints Register_19072019	The operator has established and maintains a complaint register for the power station and pipeline. No complaints were received during the audit period.	Compliant
SEMP5	Annual internal audits and annual external audits will be conducted as specified in the Operational Environmental Management Plan. These audits will assess compliance with this SEMP.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018 R_003_ERM Power_2018-2019-SEMP-Annual-Compliance Report_10122019 C_002_ERM Power_2018-2019 SEMP Annual Compliance Report & Revised SEMP_Email Sub2_12122019 R_010_ERM Power_2018-2019 Internal Audits Neerabup Pipeline OEMP OSC SEMP_11102019 C_005_ERM Power_Annual Compliance Report for the July 2017-June 2018 period_20122019	The following audits and compliance reports were prepared by ERM which assessed compliance with the SEMP: <ul style="list-style-type: none"> SEMP Annual Compliance Report submitted to DWER on 12 December 2019 Compliance Assessment Report 2018 submitted to DWER on 19 December 2019 annual internal audit was performed on the 10 and 11 October 2019. 	Compliant

Appendix E Greenhouse Gas abatement Programme audit table

Table E.1: Greenhouse Gas Abatement Programme audit table

Audit code	Action	Evidence	Comments	Status
GGAP1	Minimise/reduce energy use through the following: <ul style="list-style-type: none"> routine monitoring of plant efficiency operate plant at optimum efficiency in accordance with manufacturer's operation and maintenance. 	<p>Management advice 30 October 2019.</p> <p>D_001_ERM Power_2018-2019_Schedule 1 calcs_Audit Info Neerabup Stats_Compliance_2019</p> <p>D_002_ERM Power_Neerabup Inspection Plan 2009-2032_11052019</p> <p>D_005_ERM Power_GT11 Performance Tracking_2018</p> <p>D_006_ERM Power_GT12 Performance Tracking_2018</p> <p>D_008_ERM Power_GT11 Comp Perf tracking_2019</p> <p>D_009_ERM Power_GT12 Comp Perf tracking_2019</p> <p>R_003_ERM Power_2018-2019_SEMP-Annual-Compliance-Report_10122019</p>	<p>As previously reported, it should be noted that a power station designed and operated to provide peak supply has an inherently lower operational efficiency due to the number of start-ups against operating times and the lower efficiency of running the power plant at low outputs.</p> <p>The operator advised that there are a number of factors that could potentially influence plant efficiency including fuel quality and age of the plant. Efficiency of the plant is generally expected to gradually decline over the life of the plant. Performance monitoring is undertaken for both units with monitoring results from efficiency tests demonstrating that both turbines are operating at higher than 29.83%.</p> <p>The operator advised that the trigger item of number of starts is tracked within Neerabup Forecasted Inspection Plan 2009–2032, to indicate the appropriate timing of maintenance activities.</p> <p>Two minor inspections (routine maintenance outages) have been undertaken to date with no issues detected: First: 17 to 21 November 2014 when Unit 11 was at 273 starts and Unit 12 was at 272 starts. Second: 7 to 10 November 2017 when both Unit 11 and 12 had 523 starts.</p> <p>Start counts will dictate the date of the next minor inspection, which is anticipated to be required in April - October 2020.</p>	Conformant
GGAP2	Implement a routine preventative maintenance and cleaning regime to maintain operation of the power station at optimal efficiency.	<p>Management advice 30 October 2019.</p> <p>D_002_ERM Power_Neerabup Inspection Plan 2009-2032-11052019</p> <p>R_003_ERM Power_2018-2019- SEMP Annual-Compliance-Report_10122019</p> <p>D_007_Siemens_Neerabup Product & Service Bulletin Masterlist_2019</p>	<p>Refer to GGAP1.</p> <p>Maintenance planning schedules are in accordance with the manufacturer's requirements. Maintenance on the Neerabup gas turbines are triggered by the number of starts rather than the equivalent operating hours (EOH) due to the peaking nature of Neerabup Operations (short runs with frequent starts).</p> <p>The Siemens OEM schedules minor inspections at 250 starts (+/- 10%) or 8,000EOH whichever is earlier. Based on the current operating regime of Neerabup Power Station the 3rd minor inspections for both GT units will be due approximately April – October 2020.</p> <p>Water washes can be undertaken within the compressor if routine efficiency monitoring shows it is required; i.e. a significant decrease in compressor efficiency. Efficiency monitoring tests are used to initiate any corrective maintenance required in accordance with ongoing preventative maintenance order (PM336) in the MEX system.</p>	Conformant
GGAP3	Implement a 'continuous improvement approach' so that advances in technology and potential operational improvement of plant performance are adopted where practicable.	<p>Management advice 30 October 2019.</p> <p>R_008_ERM Power_2019 (5th – 6th Mar) V94.2 Users Group Meeting – Minutes_05032019</p>	<p>The plant utilises current technology; however, it is being reviewed to enable continuous improvement in the future. The company is represented at gas turbine user group functions which are specifically designed to address continual improvement.</p> <p>The operator actively participates in the V94.2 group which is a group established specifically for users of the V94.2 gas turbine allowing personnel to improve their sharing of experience and to promote best technical solutions. The last V94.2 Australian user group conference was attended by the operator and occurred between 5 March 2019 and 6 March 2019.</p>	Conformant
GGAP4	NewGen Power will become a member of the Greenhouse Challenge Plus Program.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	The previous Compliance Assessment Report indicated that the Greenhouse Challenge Plus Program ceased on 1 July 2009 before the NewGen Power Station became operational. Based on this, the auditors have assessed this item as Completed.	Completed
GGAP5	Annual auditing of greenhouse gas emissions.	<p>Management advice 30 October 2019.</p> <p>R_009_Clean Energy Regulator_NGERs_S19 REPORT FY1819_08102019</p> <p>C_003_ERM Power_NEE extract NGERs S19 REPORT FY1819_08102019</p>	The Proponent advised that reporting is undertaken annually under the requirements of the National Greenhouse and Energy Reporting Act 2007 (NGER). The auditor sighted the Section 19 – Energy and Emissions Report for the 2018-2019 reporting year. The report was submitted to the Clean Energy Regulator on 8 October 2019.	Conformant
GGAP6	Fund energy efficient programs in conjunction with Synergy, including the employment of a Greenhouse Program Officer.	R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	This item was deemed no longer relevant in the 2014-2015 Compliance Assessment Report and therefore the auditors have assessed it as Completed.	Completed

Audit code	Action	Evidence	Comments	Status
GGAP7	Undertake an annual review of state of the art mitigation measures to identify advances in technology and potential operational improvements of plant performance that are relevant for open-cycle gas-turbines. Investigate the feasibility of implementing these technological improvements at the NewGen Power Station.	Management advice 30 October 2019. R_008_ERM Power_2019 (5 th -6 th Mar) V94.2 Users Group Meeting- Minutes_05032019 D_007_ERM Power_Neerabup Product & Service Bulletin Masterlist_2019	As reported previously, the company is represented at gas turbine user group functions, which are specifically designed to address continual improvement (refer to GGAP3). The operator advised that Product and Service Bulletins are reviewed when received from Siemens or at a minimum annually to ensure that all corrections and operational specifications are up to date. Correction work orders are added to the list of outstanding maintenance activities compiled within the Neerabup Product and Service Bulletin – Master List. Correction work orders are typically conducted during scheduled maintenance outages. The operator also advised that personnel have access to an international forum to allow trouble shooting and sharing of information which includes potential improvements in operation. These currency measures are undertaken throughout the year in an ongoing manner, rather than once a year.	Conformant

Appendix F Banker's Audit

ERM Power
Bankers Audit
Neerabup Power Station

6 January 2020

57594-126436 (Rev 0)

JBS&G Australia Pty Ltd T/A Strategen-JBS&G

Table of Contents

1.	Introduction	3
1.1	Project background	3
2.	Audit methodology	4
2.1	Audit plan	4
2.1.1	Purpose and scope	4
2.1.1	Methodology.....	4
2.2	Audit terminology.....	5
3.	Audit results.....	6
3.1	Compliance with conditions	6

List of Tables

Table 2.1:	Approvals issued to date	4
Table 2.2:	Action implementation status.....	5
Table 3.1:	Environmental License (License Number L8356/2009/2; amended 23 October 2014) audit table.....	7
Table 3.2:	Licence to Take Water (GWL164093(5)) Issued 28 June 2011 (applicable to both bores – Licence valid from 28 June 2011 to 18 May 2021) audit table	13

1. Introduction

This report addresses the status and compliance of environmental and planning approvals granted for the Neerabup Gas-Fired Power Station. This report has been prepared for the purpose of meeting a requirement of the banker's conditions to submit an annual compliance report.

1.1 Project background

NewGen Neerabup Partnership (NewGen) is the Proponent for a proposal to construct and operate:

- a 330 megawatt open-cycle gas-turbine power station
- a 30 kilometre long gas pipeline and compressor station to transport natural gas from the Dampier to Bunbury Natural Gas Pipeline to the power station
- a 330 kilovolt electricity transmission line, approximately two kilometres long, to connect the power station to the Western Power Neerabup terminal substation.

The Minister for the Environment issued Ministerial Statement (MS) 759 on 21 January 2008, under Part IV of the *Environmental Protection Act 1986 (EP Act)*, enabling the proposal to be implemented. A number of subsequent environmental and planning approvals have also been granted.

The power station is located at Neerabup, approximately 30 km north of Perth. The power station provides additional power into the South West Interconnected System (SWIS) during times of peak demand.

NewGen led the development and project financing for the Neerabup power station. ERM Power was the project and construction manager and is currently the operator of the facility.

2. Audit methodology

2.1 Audit plan

2.1.1 Purpose and scope

This document has been prepared for NewGen to fulfil the requirement of submitting a third-party annual compliance review. Specifically, the compliance review is required for the approvals that have been issued to date in relation to the NewGen Neerabup Power Station, including gas pipeline and transmission line (Table 2.1).

This audit report addresses the period from 31 July 2018 to 30 June 2019.

Table 2.1: Approvals issued to date

Relevant approval	Identification No.	Issue date
Implementation Statement that permits the implementation of the proposal pursuant to Part IV of the <i>Environmental Protection Act 1986</i> .	Statement 759.	21 January 2008.
Works Approval pursuant to Part V of the <i>Environmental Protection Act 1986</i> .	W4/2008/1.	17 April 2008.
Environmental Licence for prescribed premise pursuant to Part V of the <i>Environmental Protection Act 1986</i> and Schedule 1 Category 52 of the <i>Environmental Protection Regulations 1987</i> .	L8356/2009/2	4 December 2009 (amended 27 March 2013, 5 August 2013 and 23 October 2014). Expires 2 December 2035
Licence to Construct or Alter Well pursuant to the <i>Rights in Water and Irrigation Act 1914</i> .	RF2083, CAW168369(1).	23 January 2009.
Licence to Take Water pursuant to the <i>Rights in Water and Irrigation Act 1914</i> (Water Licence).	RF2083, GWL164093(2). RF2083, GWL164093(5).	23 January 2009 (re-issued 2 February 2010 and 28 June 2011).
WAPC Development Approval for power station under the provisions of the Metropolitan Region Scheme.	30-50179-1.	23 April 2008.
WAPC Development Approval for gas pipeline and transmission line under the provisions of the Metropolitan Region Scheme.	30-50179-2.	27 October 2008.
City of Wanneroo Development Approval for power station under the provisions of the Wanneroo District Planning Scheme No. 2.	DA07/1107.	17 March 2008.
City of Wanneroo Development Approval for gas pipeline and transmission line under the provisions of the Wanneroo District Planning Scheme No. 2.	DA08/0667.	4 September 2008.
Notice of Amendment for Environmental Licence for prescribed premise pursuant to Part V of the <i>Environmental Protection Act 1986</i> and Schedule 1 Category 52 of the <i>Environmental Protection Regulations 1987</i> .	L8356/2009/2	29 April 2016

Notes:

- compliance with MS 759 is assessed in the annual Compliance Assessment Report (Strategen 2019 - to which this report is appended)
- Works Approval was not audited as the conditions contained in the Works Approval were all completed during the Banker's Audit prepared in 2010
- Licence to Construct or Alter Well (CAW 168369(1)) expired in July 2009 and did not form part of this audit
- WAPC Development Approval for the power station has no relevant conditions and was not part of this audit
- WAPC Development Approval (Gas Pipeline and Transmission Line) is no longer relevant and did not form part of this audit
- City of Wanneroo Development Approval (Gas Pipeline and Transmission) is no longer relevant since the construction phase is complete, and did not form part of this audit.

1.1.1 Methodology

The site component of the audit was undertaken by Elizabeth Payne and Rebecca Mason (Strategen-JBS&G) on 30 October 2019 addressing the period from 1 July 2018 to 30 June 2019. The audit included interviews with the Neerabup Power Station Manager, Bruno Lanciano, and review of key documents supplied by ERM Power.

2.2 Audit terminology

The 'Status' field of the audit tables (refer to Table 3.1; Table 3.2) describes the implementation of actions and compliance with the Statement. The Department of Water and Environmental Regulation (DWER) (previously called OEPA) prepared guidance related to the preparation of compliance audits, including generic expressions that are used to identify the status of each action. The auditor applied the terminology in Table 2.2 to complete the status field of the audit tables.

Table 2.2: Action implementation status

Status	Description
Compliant/conformant.	Implementation of the proposal has been carried out in accordance with requirements of the audit element.
Completed.	A requirement with a finite period of application has been satisfactorily completed.
Not required at this stage.	The requirements of the audit element were not triggered during the reporting period.
Potentially non-compliant/Potentially non-conformant.	Possible or likely failure to meet the requirements of the audit element.
In process.	Where an audit element requires a management or monitoring plan be submitted to the DWER or another government agency for approval, that submission has been made and no further information or changes have been requested by the DWER or the other government agency and assessment by the DWER or other government agency for approval is still pending.
Not audited.	Unable to be audited.

Source: adapted from OEPA (2012a, 2012b, 2012c and 2012d) – note that the 'Not audited' status has been added for items that were unable to be audited.

3. Audit results

3.1 Compliance with conditions

Full results of the assessment of compliance associated with this Banker's Audit are provided in the following audit tables, specifically:

- Environmental licence (L8356/2009/2) (refer to Table 3.1)
- Water Licence (GWL164093(5)) (refer to Table 3.2).

Table 3.1: Environmental License (License Number L8356/2009/2; amended 23 October 2014) audit table

I.D Code	Requirement	Evidence	Comments	Status
L8356-2009-2: 1.2.1	Nothing in this Licence shall be taken to authorise any emission that is not mentioned in this licence, where the emission amounts to: (a) pollution; (b) unreasonable emission; (c) discharge of waste in circumstances likely to cause pollution; or (d) being contrary to any written law.	Management advice 30 October 2019. Site inspection 30 October 2019. D_004_ERM Power_Incident Register_15052017 D_003_ERM Power_NPS-REG-ECT-COMP External Complaints Register_19072019	No unauthorised emissions were observed during the site inspection. There were no recordable incidents or complaints during the audit period relating to emissions and/or pollution.	Compliant
L8356-2009-2: 1.2.2	The Licensee shall operate and maintain all pollution control and monitoring equipment to the manufacturer's specification or any relevant and effective internal management system.	Management advice 30 October 2019. Site inspection 30 October 2019. R_001_Strategen-JBS&G_2013-2014-Neerabup-Environmental-Compliance-Report_10122019 D_002_ERM Power_Neerabup Inspection Plan 2009-2032_11052019	As reported previously, there are no specific additional air pollution control equipment at the power station. The gas turbines themselves are modern low NOx burners. Maintenance planning schedules are in accordance with the manufacturer's requirements. Maintenance on the Neerabup gas turbines are triggered by the number of starts rather than the equivalent operating hours (EOH) due to the peaking nature of Neerabup Operations (short runs with frequent starts). The Siemens OEM schedules minor inspections at 250 starts (+/- 10%) or 8,000EOH whichever is earlier. The operator advised that the trigger item of number of starts is tracked within Neerabup Forecasted Inspection Plan 2009–2032, to indicate the appropriate timing of maintenance activities. Two minor inspections (routine maintenance outages) have been undertaken to date with no issues detected: First: 17 to 21 November 2014 when Unit 11 was at 273 starts and Unit 12 was at 272 starts. Second: 7 to 10 November 2017 when both Unit 11 and 12 had 523 starts. Based on the current operating regime of Neerabup Power Station the 3rd minor inspections for both GT units will be due approximately between April 2020- October 2020. Monitoring equipment is maintained and calibrated to maintain NATA accreditation for contractors engaged to undertake air emissions and groundwater monitoring.	Compliant
L8356-2009-2: 1.2.3	The Licensee, except where storage is prescribed in section 1.3, shall ensure that environmentally hazardous substances are stored in accordance with the Code of Practice for the Storage of dangerous goods.	Management advice 30 October 2019. Site inspection 30 October 2019. P_003_Strategen-JBS&G_Chemical storage bunding_30102019 P_004_Strategen-JBS&G_Chemical storage shed_30102019 D_010_ERM Power_NPS-REG-HAZ-01 Hazardous Substance MSDS Register	The site inspection confirmed that environmentally hazardous material is stored appropriately (P_003; P_004). Site observations included: <ul style="list-style-type: none">all chemicals and hydrocarbons are stored in bunded areasa chemical storage shed is available, of which the floor is concrete, bunded and graded for spills to be collected in a sumpthe fuel storage tank associated with the emergency diesel generator is self-bundedall reject water is directed to the collection pondsite stormwater us directed to the soakage pitall transmission areas are bunded and constructed in such a way that spills can be collected and removed from site. Process includes an oily water separatorMSDS register is maintained for all hazardous goods stored on site	Compliant
L8356-2009-2: 1.2.4	The Licensee shall immediately recover or remove and dispose of spills of environmentally hazardous materials outside an engineered containment system.	Management advice 30 October 2019. Site inspection 30 October 2019. R_004_ERM Power_2018-2019 NewGen Neerabup DWER Annual Monitoring & Compliance Report_07082019 D_004_ERM Power_Incident Register_15052017	No reportable spills were recorded during the audit period.	N/A
L8356-2009-2: 1.2.5	The Licensee shall: (a) implement all practical measures to prevent stormwater run-off becoming contaminated by the activities on the Premises; and (b) treat contaminated or potentially contaminated stormwater as necessary prior to being discharged from the Premises. ¹ Note1: The Environmental Protection (Unauthorised Discharges) Regulations 2004 make it an offence to discharge certain materials into the environment.	Management advice 30 October 2019. Site inspection 30 October 2019. P_005_Strategen-JBS&G_Evaporation pond_30102019 P_006_Strategen-JBS&G_Stormwater pit_30102019	The site inspection confirmed that all potentially contaminated stormwater is collected and treated on site. Site observations included: <ul style="list-style-type: none">site stormwater is directed to the soakage pitall transmission areas are bunded and drain to the concrete lined potentially contaminated stormwater pit	Compliant

I.D Code	Requirement	Evidence	Comments	Status												
			<ul style="list-style-type: none"> an oily water separator is used to separate oil from contaminated stormwater, water can be released from the oily water pit to the site's soakage pit if it is acceptable to do so as defined by the site procedures. Oil is collected and disposed of off-site via an authorised disposal facility as required, however this is yet to occur. 													
L8356-2009-2: 1.3.1	The Licensee shall divert all reject water from the Demineralised Water Plant to the evaporation ponds as depicted in Schedule 1.	Management advice 30 October 2019. Site inspection 30 October 2019. P_006_Strategen-JBS&G_Evaporation pond_30102019	The site inspection confirmed that systems are in place to divert all reject water from the demineralised water plant to the evaporation pond.													
Emissions																
L8356-2009-2: 2.1.1	The Licensee shall record and investigate the exceedance of any descriptive or numerical limit or target specified in any part of section 2 of this Licence.	Management advice 30 October 2019. Site inspection 30 October 2019. R_003_ERM Power_2018-2019-SEMP-Annual Compliance Report_10122019 R_004_ERM Power_2018-2019 NewGen Neerabup DWER Annual Monitoring & Compliance Report_07082019	No exceedances of air emissions targets were recorded during the audit period.	Compliant												
L8356-2009-2: 2.2.1	The Licensee shall use ensure that where waste is emitted to air from the emission points in Table 2.2.1 and identified on the map of emission points in Schedule 1 it is done so in accordance with the conditions of this licence. Table 2.2.1: Point source emissions points to air <table border="1" data-bbox="394 932 1205 1100"> <thead> <tr> <th>Emission point reference</th> <th>Emission point</th> <th>Emission point height (m)</th> <th>Source, including any abatement</th> </tr> </thead> <tbody> <tr> <td>A1</td> <td>Unit 11</td> <td>35</td> <td>165 MWe open cycle Gas Turbine Unit 11, fitted with low NOx burners</td> </tr> <tr> <td>A2</td> <td>Unit 12</td> <td>35</td> <td>165 MWe open cycle Gas Turbine Unit 12, fitted with low NOx burners</td> </tr> </tbody> </table>	Emission point reference	Emission point	Emission point height (m)	Source, including any abatement	A1	Unit 11	35	165 MWe open cycle Gas Turbine Unit 11, fitted with low NOx burners	A2	Unit 12	35	165 MWe open cycle Gas Turbine Unit 12, fitted with low NOx burners	Management advice 30 October 2019. Site inspection 30 October 2019. R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	Design and construction occurred outside of the audit period relevant to this report. The power station was constructed with low NOx burners and air emissions are discharged from the stacks fitted to the gas turbine units.	Compliant
Emission point reference	Emission point	Emission point height (m)	Source, including any abatement													
A1	Unit 11	35	165 MWe open cycle Gas Turbine Unit 11, fitted with low NOx burners													
A2	Unit 12	35	165 MWe open cycle Gas Turbine Unit 12, fitted with low NOx burners													
L8356-2009-2: 2.2.2	The Licensee shall target point source emissions to air at or below the levels specified in Table 2.2.2. Table 2.2.2: Point source emission targets to air <table border="1" data-bbox="394 1184 1205 1304"> <thead> <tr> <th>Emission point reference</th> <th>Parameter</th> <th>Target (including units)^{1,2}</th> <th>Averaging period</th> </tr> </thead> <tbody> <tr> <td>A1, A2</td> <td>NOx</td> <td>51 mg/Nm³ 25 ppmvd</td> <td>60 minute average</td> </tr> </tbody> </table> Note 1: All units are referenced to STP dry. Note 2: All units are referenced to 15% O ₂ . Note 3: Target values do not apply during start-up, shutdown and if the gas turbines are operating below 60% maximum load.	Emission point reference	Parameter	Target (including units) ^{1,2}	Averaging period	A1, A2	NOx	51 mg/Nm ³ 25 ppmvd	60 minute average	Management advice 30 October 2019. Site inspection 30 October 2019. R_003_ERM Power_2018-2019-SEMP_Annual Compliance Report_10122019 R_004_ERM Power2018-2019 Newgen Neerabup DWER Annual Monitoring & Compliance Report_07082019	Gas turbines are fitted with low NOx burners. NOx emissions from Unit 11 and Unit 12 were compliant during the audit period (38mg/Nm ³ and 20mg/Nm ³ respectively). Stack emissions testing was undertaken in January 2019 during required operating loads and NOx measurements were reported using the appropriate units.	Compliant				
Emission point reference	Parameter	Target (including units) ^{1,2}	Averaging period													
A1, A2	NOx	51 mg/Nm ³ 25 ppmvd	60 minute average													
Monitoring																
L8356-2009-2: 3.1.1	The licensee shall ensure that: (a) all water samples are collected and preserved in accordance with AS/NZS 5667.1; (b) all groundwater sampling is conducted in accordance with AS/NZS 5667.11; (c) all samples are submitted to a laboratory with current NATA accreditation for the parameters to be measured.	R_004_ERM Power_2018-2019 NewGen Neerabup DWER Annual monitoring & Compliance Report_07082019	Groundwater samples were collected by 360 Environmental as per: <ul style="list-style-type: none"> AS/NZS 5667.1:1998 Water Quality Sampling. Part I – Guidance on the Design of Sampling Programs, Sampling Techniques and the Preservation and Handling of Samples AS/NZS 5667.11:1998 Water Quality Sampling. Part II – Guidance on Sampling of Groundwater. Samples were analysed by Eurofins MGT laboratories (NATA Accredited).	Compliant												
L8356-2009-2: 3.1.2	The Licensee shall ensure that: (a) six monthly monitoring is undertaken at least 5 months apart; and (b) annual monitoring is undertaken at least 9 months apart.	Management advice 30 October 2019. Site inspection 30 October 2019. R_004_ERM Power_2018-2019 NewGen Neerabup DWER Annual Monitoring & Compliance Report_07082019	Licence L8356/2009/2 was issued on 23 October 2014 specifying a reduced frequency for the groundwater monitoring program (from six monthly to annually). Annual groundwater sampling was completed on 25 October 2018, this is at least nine months apart from the previous reporting period sampling, which was undertaken on the 4 October 2017. Annual air emissions stack testing monitoring was conducted on 1 and 8 of January 2019, this is at least nine months apart from the previous reporting period, whereby testing was complete on 8 and 12 November 2017.	Compliant												
L8356-2009-2: 3.1.3	The Licensee shall record production or throughput data and any other process parameters relevant to any non-continuous or CEMS monitoring undertaken.	Management advice 30 October 2019.	CEMS equipment has been decommissioned as requirement for CEMS monitoring has been removed from license by earlier amendments.	Compliant												

I.D Code	Requirement	Evidence	Comments	Status																
		D_001_ERM Poweer_2018-2019_Schedule 1 calcs_Audit info Neerabup Stats_Compliance_2019 D_005_ERM Power_GT11 Performance Tracking_2018 D_006_ERM Power_GT12 Performance Tracking_2018 D_008_ERM Power_GT11 Comp Perf tracking_2019 D_009_ERM Power_GT12 Comp Perf tracking_2019	Performance tracking is undertaken for both units.																	
L8356-2009-2: 3.1.4	The Licensee shall ensure that all monitoring equipment used on the Premises to comply with the conditions of this Licence is calibrated in accordance with the manufacturer's specifications.	Management advice 30 October 2019. R_004_ERM Power_2018-2019 NewGen Neerabup DWER Annual Monitoring & Compliance Report_07082019	The DWER annual Monitoring and Compliance report indicates that the monitoring equipment used by contractors for air and water monitoring are calibrated in accordance with relevant Australian and international standards. Monitoring of power output from the facility is undertaken outside of the premises by Western Power. The operator advised that Western Power undertakes regular calibration of the metering equipment.	Compliant																
L8356-2009-2: 3.1.5	The Licensee shall, where the requirements for calibration cannot be practically met, or a discrepancy exists in the interpretation of the requirements, bring these issues to the attention of the Director accompanied with a report comprising details of any modifications to the methods.	Management advice 30 October 2019. R_003_ERM Power_2018-2019-SEMP-Annual-Compliance-Report_10012019 D_004_ERM Power_Incident Register_15052017	There were no incidences where the requirements for calibration were not practically met, or a discrepancy in the interpretation of the requirements existed. Therefore, a report on any modifications to the calibration methods is not required at this stage.	N/A																
L8356-2009-2: 3.2.1	The Licensee shall undertake the monitoring in Table 3.2.1 according to the specifications in that table. Table 3.2.1: Monitoring of point source emissions to air <table border="1" data-bbox="388 1150 1308 1325"> <thead> <tr> <th>Emission point reference</th> <th>Parameter</th> <th>Units^{1,3}</th> <th>Frequency²</th> <th>Method</th> </tr> </thead> <tbody> <tr> <td rowspan="3">A1, A2</td> <td>NOx</td> <td>mg/m³ g/s</td> <td rowspan="3">Annually</td> <td>USEPA Method 7E</td> </tr> <tr> <td>CO</td> <td>mg/m³ g/s</td> <td>USEPA Method 10</td> </tr> <tr> <td>Stack gas velocity</td> <td>m/s</td> <td>USEPA Method 2</td> </tr> </tbody> </table> Note 1: All units are referenced to STP dry. Note 2: Monitoring shall be undertaken to reflect normal operating conditions and any limits or conditions on inputs or production such that minimum output per gas turbine at all times during the testing is maintained at 100 MWe and variation of no more than ±5% is observed at all times during the testing. Note 3: All units are referenced to 15% O ₂ .	Emission point reference	Parameter	Units ^{1,3}	Frequency ²	Method	A1, A2	NOx	mg/m ³ g/s	Annually	USEPA Method 7E	CO	mg/m ³ g/s	USEPA Method 10	Stack gas velocity	m/s	USEPA Method 2	Management advice 30 October 2019. R_003_ERM Power_2018-2019-SEMP-Annual-Compliance-Report_10012019	Annual stack emissions testing was conducted on: <ul style="list-style-type: none"> unit 11 – 7 January 2019 unit 12 – 7 January 2019. The results of these tests were within the defined limits. Testing was undertaken in accordance with the specifications of this licence condition.	Compliant
Emission point reference	Parameter	Units ^{1,3}	Frequency ²	Method																
A1, A2	NOx	mg/m ³ g/s	Annually	USEPA Method 7E																
	CO	mg/m ³ g/s		USEPA Method 10																
	Stack gas velocity	m/s		USEPA Method 2																
L8356-2009-2: 3.2.2	The Licensee shall ensure that all non-continuous sampling and analysis undertaken pursuant to condition 3.2.1 is undertaken by a holder of NATA accreditation for the relevant methods of sampling and analysis.	R_003_ERM Power_2018-2019-SEMP-Annual-Compliance-Report_10012019 R_004_ERM Power_2018-2019 NewGen Neerabup DWER annual Monitoring & Compliance Report_07082019	Ektimo Pty Ltd are NATA accredited (NATA accreditation No. 14601) for the sampling and analysis undertaken as part of the stack emissions monitoring program.	Compliant																
L8356-2009-2: 3.7.1	The Licensee shall monitor and record parameters specified in Table 1.3.1 according to the specifications in that table. The recorded data shall be reported in cumulative monthly totals. Table 3.7.1: Load monitoring parameters to be recorded <table border="1" data-bbox="388 1738 1308 1877"> <thead> <tr> <th>Parameter</th> <th>Units</th> <th>Frequency</th> </tr> </thead> <tbody> <tr> <td>Run time</td> <td>Hours</td> <td rowspan="3">Monthly</td> </tr> <tr> <td>Total electrical energy generated</td> <td>MWh</td> </tr> <tr> <td>Operating capacity</td> <td>%</td> </tr> </tbody> </table>	Parameter	Units	Frequency	Run time	Hours	Monthly	Total electrical energy generated	MWh	Operating capacity	%	D_001_ERM Power_2018-2019_Schedule 1 calcs_Audit Info Neerabup Stats_Compliance_2019	Cumulative monthly totals are recorded for the parameters listed in Column 1 of Table 3.7.1.	Compliant						
Parameter	Units	Frequency																		
Run time	Hours	Monthly																		
Total electrical energy generated	MWh																			
Operating capacity	%																			

I.D Code	Requirement	Evidence	Comments	Status																		
L8356-2009-2: 3.8.1	<p>The Licensee shall undertake the monitoring specified in Table 3.8.1 and record and investigate the exceedance of any target specified.</p> <p>Table 3.8.1: Monitoring of ambient groundwater quality</p> <table border="1"> <thead> <tr> <th>Monitoring point reference and location</th> <th>Parameter</th> <th>Units</th> <th>Averaging period</th> <th>Frequency</th> </tr> </thead> <tbody> <tr> <td rowspan="5">GW1, GW2, GW3, GW4, GW5, GW6, GW7</td> <td>pH</td> <td>-</td> <td rowspan="5">Spot sample</td> <td rowspan="5">Annually</td> </tr> <tr> <td>Total dissolved solids</td> <td>mg/L</td> </tr> <tr> <td>Conductivity</td> <td>µS/cm</td> </tr> <tr> <td>Total nitrogen</td> <td>mg/L</td> </tr> <tr> <td>Total recoverable hydrocarbons</td> <td>mg/L</td> </tr> </tbody> </table>	Monitoring point reference and location	Parameter	Units	Averaging period	Frequency	GW1, GW2, GW3, GW4, GW5, GW6, GW7	pH	-	Spot sample	Annually	Total dissolved solids	mg/L	Conductivity	µS/cm	Total nitrogen	mg/L	Total recoverable hydrocarbons	mg/L	R_004_ERM Power_2018-2019 NewGen Neerabup DWER Annual Monitoring & Compliance Report_07082019	<p>Groundwater was sampled and analysed in October 2018 in accordance with Table 3.8.1.</p> <p>There are no targets for ambient groundwater quality specified in the licence. The 2018 Groundwater Monitoring Report prepared following the October 2018 sampling event states that no new groundwater impacts were observed as a result of site operations.</p> <p>The following conclusions were made:</p> <ul style="list-style-type: none"> concentrations of TN exceeding the adopted FWG criteria are likely to be the result of neighbouring land uses, including an active market garden and a chicken farm, rather than as a result of Power Station operations it is unlikely that the Power Station operations have had a significant impact on the quality of groundwater beneath the site the occurrence of the elevated nutrient concentrations in groundwater at the site, are unlikely to result in significant impact. 	Compliant
Monitoring point reference and location	Parameter	Units	Averaging period	Frequency																		
GW1, GW2, GW3, GW4, GW5, GW6, GW7	pH	-	Spot sample	Annually																		
	Total dissolved solids	mg/L																				
	Conductivity	µS/cm																				
	Total nitrogen	mg/L																				
	Total recoverable hydrocarbons	mg/L																				
Information																						
L8356-2009-2: 5.1.1	All information and records required by the Licence shall: <ul style="list-style-type: none"> (a) be legible; (b) if amended, be amended in such a way that the original and subsequent amendments remain legible or are capable of retrieval; (c) except for records listed in 5.1.1 (d) be retained for at least 6 years from the date the records were made or until the expiry of the Licence or any subsequent licence; and (d) for those following records, be retained until the expiry of the Licence and any subsequent licence: <ul style="list-style-type: none"> (i) off-site environmental effects; or (ii) matters which affect condition of the land or waters. 	Management advice 30 October 2019.	Records that are required by this licence (including original and subsequent amendments) are stored on the local server that is replicated in the Brisbane head office and backed up on duplicate servers.	Compliant																		
L8356-2009-2: 5.1.2	The Licensee shall ensure that: <ul style="list-style-type: none"> (a) any person left in charge of the Premises is aware of the conditions of the Licence and has access at all times to the Licence or copies thereof; and (b) any person who performs tasks on the Premises is informed of all of the conditions of the Licence that relate to the tasks which that person is performing. 	Management advice 30 October 2019.	<p>Staff that are 'left in charge of the Premises' include the Power Station Manager and, in their absence, the acting Station Manager/2IC. The Power Station Manager was interviewed for this audit and was aware of the licence conditions. The position descriptions for the Power Station Manager and Operations Engineer Support (acting Station Manager/2IC) outline their responsibilities for ensuring compliance with regulatory requirements. The Power Station Manager understands the requirement to delegate responsibility for ensuring compliance with licence conditions in their absence.</p> <p>Access to all staff at all times to copies of this licence is provided through the local computer network. All staff and contractors performing work within the site are required to undertake a site induction which outlines their obligations under the EP Act and specific requirements of regulatory approvals.</p>	Compliant																		
L8356-2009-2: 5.1.3	The Licensee shall complete an Annual Audit Compliance Report indicating the extent to which the Licensee has complied with the conditions of the Licence, and any previous licence issued under Part V of the Act for the Premises for the previous annual period.	<p>Management advice 30 October 2019.</p> <p>R_004_ERM Power_2018-2019 NewGen Neerabup DWER Annual Monitoring & Compliance Report_07082019</p> <p>C_001_ERM Power_190814 2018-2019 NNP DWER Annual Monitoring & Compliance Report Submission Email-2_14082019</p>	An Annual Audit Compliance Report (AACR) was prepared in the form specified in Schedule 2 of the licence. This AACR addresses compliance with L8356/2009/2 during the reporting period 1 July 2018 to 30 June 2019 and was sent to the DWER on 14 August 2019.	Compliant																		
L8356-2009-2: 5.1.4	The Licensee shall implement a complaints management system that as a minimum records the number and details of complaints received concerning the environmental impact of the activities undertaken at the Premises and any action taken in response to the complaint.	<p>Management advice 30 October 2019.</p> <p>D_003_ERM Power_NPS-REG-EXT-COMP External Complaints Register_19072019</p>	An external complaints procedure is initiated on receiving a complaint which requires recording the details of the complaint and any remedial actions taken.	Compliant																		
L8356-2009-2: 5.2.1	<p>The Licensee shall submit to the Director at the Contact Address an Annual Environmental Report by 31 August each year after the end of the annual period. The report shall contain the information listed in Table 5.2.1 in the format or form specified in that table.</p> <p>Table 5.2.1: Annual Environmental Report</p> <table border="1"> <thead> <tr> <th>Condition or table (if relevant)</th> <th>Parameter</th> <th>Format or form1</th> </tr> </thead> <tbody> <tr> <td>-</td> <td>Summary of any failure or malfunction of any pollution control equipment or any incidents that have occurred during the annual period and any action taken</td> <td>None specified</td> </tr> </tbody> </table>	Condition or table (if relevant)	Parameter	Format or form1	-	Summary of any failure or malfunction of any pollution control equipment or any incidents that have occurred during the annual period and any action taken	None specified	<p>Management advice 30 October 2019.</p> <p>R_004_ERM Power_2018-2019 NEWGEN Neerabup DWER Annual Monitoring & Compliance Report_07082019</p> <p>C_001_ERM Power_190814 2018-2019 NNP DWER Annual Monitoring & Compliance Report Submission Email-2_14082019</p>	<p>An annual monitoring report addressing the reporting period 1 July 2018 to 30 June 2019 was prepared in accordance with the amended licence conditions issued on 23 October 2014. The report contained the information listed in Table 5.2.1 in the format specified in that table.</p> <p>The report was submitted to DWER on 14 August 2019.</p>	Compliant												
Condition or table (if relevant)	Parameter	Format or form1																				
-	Summary of any failure or malfunction of any pollution control equipment or any incidents that have occurred during the annual period and any action taken	None specified																				

I.D Code	Requirement	Evidence	Comments	Status																					
	<table border="1"> <tr> <td>Table 2.2.2, 2.1.1</td> <td>Target exceedances</td> <td>None specified</td> </tr> <tr> <td></td> <td>Summary of any data exceeding targets, including information on why the exceedance occurred and action taken by the Licensee to prevent recurrence of such exceedance</td> <td></td> </tr> <tr> <td>Table 3.2.1</td> <td>Annual stack monitoring results for NOx, CO and stack gas velocity</td> <td>AR1</td> </tr> <tr> <td>Table 3.8.1</td> <td>Groundwater quality monitoring results</td> <td>GR1</td> </tr> <tr> <td>Table 3.7.1</td> <td>Cumulative monthly total of each parameter recorded as specified in condition 3.7.1</td> <td></td> </tr> <tr> <td>5.1.3</td> <td>Compliance</td> <td>Annual Audit Compliance Report (AACR)</td> </tr> <tr> <td>5.1.4</td> <td>Complaints summary</td> <td>None specified</td> </tr> </table> <p>Note 1: Forma are in Schedule 2</p>	Table 2.2.2, 2.1.1	Target exceedances	None specified		Summary of any data exceeding targets, including information on why the exceedance occurred and action taken by the Licensee to prevent recurrence of such exceedance		Table 3.2.1	Annual stack monitoring results for NOx, CO and stack gas velocity	AR1	Table 3.8.1	Groundwater quality monitoring results	GR1	Table 3.7.1	Cumulative monthly total of each parameter recorded as specified in condition 3.7.1		5.1.3	Compliance	Annual Audit Compliance Report (AACR)	5.1.4	Complaints summary	None specified			
Table 2.2.2, 2.1.1	Target exceedances	None specified																							
	Summary of any data exceeding targets, including information on why the exceedance occurred and action taken by the Licensee to prevent recurrence of such exceedance																								
Table 3.2.1	Annual stack monitoring results for NOx, CO and stack gas velocity	AR1																							
Table 3.8.1	Groundwater quality monitoring results	GR1																							
Table 3.7.1	Cumulative monthly total of each parameter recorded as specified in condition 3.7.1																								
5.1.3	Compliance	Annual Audit Compliance Report (AACR)																							
5.1.4	Complaints summary	None specified																							
L8356-2009-2: 5.2.2	The Licensee shall ensure that the Annual Environmental Report also contains: (a) any relevant process, production or operational data recorded under Condition 3.1.3; and (b) an assessment of the information contained within the report against previous monitoring results and Licence limits and/or targets.	Management advice 30 October 2019. R_004_ERM Power_2018-2019 NEWGEN Neerabup DWER Annual Monitoring & Compliance Report_07082019	The annual monitoring report contained data recorded under licence condition 3.1.3 including production data. The environmental monitoring data recorded during the reporting period was assessed against data recorded over previous reporting periods and Licence targets.	Compliant																					
L8356-2009-2: 5.2.3	The Licensee shall submit the information in Table 5.2.2 to the CEO according to the specifications in that table. Table 5.2.2: Non-annual reporting requirements	Management advice 30 October 2019. R_004_ERM Power_2018-2019 NEWGEN Neerabup DWER Annual Monitoring & Compliance Report_07082019 C_001_ERM Power_190814 2018-2019 NNP DWER Annual Monitoring & Compliance Report Submission Email-2_14082019	There were no requests made by DWER for copies of original monitoring reports. The air emission monitoring report and groundwater monitoring report containing results from monitoring undertaken during the audit period were submitted to DWER as part of the DWER Annual Environmental and Audit Compliance Report on 14 August 2019.	Compliant																					
	<table border="1"> <thead> <tr> <th>Condition or table (if relevant)</th> <th>Parameter</th> <th>Reporting period</th> <th>Reporting date (after end of the reporting period)</th> <th>Format or form1</th> </tr> </thead> <tbody> <tr> <td>-</td> <td>Copies of original monitoring reports submitted to the Licensee by third parties</td> <td>Not Applicable</td> <td>Within 14 days of the CEOs request</td> <td>As received by the Licensee from third parties</td> </tr> </tbody> </table>	Condition or table (if relevant)	Parameter	Reporting period	Reporting date (after end of the reporting period)	Format or form1	-	Copies of original monitoring reports submitted to the Licensee by third parties	Not Applicable	Within 14 days of the CEOs request	As received by the Licensee from third parties														
Condition or table (if relevant)	Parameter	Reporting period	Reporting date (after end of the reporting period)	Format or form1																					
-	Copies of original monitoring reports submitted to the Licensee by third parties	Not Applicable	Within 14 days of the CEOs request	As received by the Licensee from third parties																					
L8356-2009-2: 5.3.1	The Licensee shall ensure that the parameters listed in Table 5.3.1 are notified to the CEO in accordance with the notification requirements of the table. Table 5.3.1: Notification requirements	Management advice 30 October 2019. R_004_ERM Power_2018-2019 NEWGEN Neerabup DWER Annual Monitoring & Compliance Report_07082019	As previously stated in L8356-2009-2: 3.1.5, monitoring equipment used on site has been appropriately calibrated to date and therefore a report on any modifications to the calibration methods is not required at this stage. As stated in L8356-2009-2: 2.1.1, there were no exceedance of air emission targets recorded during the audit period. No notifications were required as no target exceedances occurred, and no failure or malfunction of any pollution control equipment occurred. There were no releases of freshwater from the reverse osmosis plant to the soak pit.	N/A																					
	<table border="1"> <thead> <tr> <th>Condition or table (if relevant)</th> <th>Parameter</th> <th>Notification requirement1</th> <th>Format or form2</th> </tr> </thead> <tbody> <tr> <td>3.1.5</td> <td>Calibration report</td> <td>As soon as practicable</td> <td>None specified</td> </tr> <tr> <td>2.1.1</td> <td>Target exceedance</td> <td>Notification required as soon as practicable but no later than 5pm of the next usual working day. Exceedance report to be submitted no later than 7 usual working days</td> <td>ET1</td> </tr> </tbody> </table>	Condition or table (if relevant)	Parameter	Notification requirement1	Format or form2	3.1.5	Calibration report	As soon as practicable	None specified	2.1.1	Target exceedance	Notification required as soon as practicable but no later than 5pm of the next usual working day. Exceedance report to be submitted no later than 7 usual working days	ET1												
Condition or table (if relevant)	Parameter	Notification requirement1	Format or form2																						
3.1.5	Calibration report	As soon as practicable	None specified																						
2.1.1	Target exceedance	Notification required as soon as practicable but no later than 5pm of the next usual working day. Exceedance report to be submitted no later than 7 usual working days	ET1																						

I.D Code	Requirement			Evidence	Comments	Status
	<ul style="list-style-type: none"> - Any failure or malfunction of any pollution control equipment or any incident which has caused, is causing or may cause pollution - 	Part A: As soon as practicable but no later than 5pm of the next usual working day. Part B: As soon as practicable but no later than 5 usual working days	N1			
	Any confirmed discharge of freshwater from the reverse osmosis plants to the stormwater soak pit.	As soon as practicable	None specified			
	Note 1: Notification requirements in the licence shall not negate the requirement to comply with s72 of the Act. Note 2: Forms are in Schedule 2.					

Table 3.2: Licence to Take Water (GWL164093(5)) Issued 28 June 2011 (applicable to both bores – Licence valid from 28 June 2011 to 18 May 2021) audit table

#	Associated conditions (Licence to take Water)	Evidence	Comments	Status
1	That should the licensee's draw adversely affect the aquifer or other users in the area, the Department of Water may reduce the amount that may be drawn.	N/A.	This item has been taken as a note.	Not audited.
2	Approval by the Department of Water is to be obtained prior to the construction of additional and replacement wells and the modification or refurbishment of existing wells.	ERM Power advice 30 October 2019. Site inspection 30 October 2019.	No additional wells required. None of the existing wells were modified or refurbished.	N/A
3	The licensee must install a cumulative water meter of a type approved under the Rights in Water and Irrigation (Approved Meters) Order 2009 to each water draw point under this licence.	Management advice 30 October 2019. R_001_Strategen-JBS&G_Neerabup Power Station CAR 2018_18122018	As reported last year, the water meter has been installed in accordance with the requirements of the Rights in Water and Irrigation (Approved Meters) Order 2009. The operator advised that a five-yearly interval for calibration has been deemed to be appropriate. This was determined in communication with the manufacturer and the Department of Water. Bore 1 and Bore 2 were last calibrated on 23 June 2016. Both bores are next due for calibration on 23 June 2021. This maintenance will be tracked through the work order system. Calibration certificates state that the water meters are acceptable in accordance with relevant Australian Standards.	Compliant
4	The meter(s) must be installed in accordance with the provisions of the document entitled 'Guidelines for Water Meter Installation 2009' before any water is taken under this licence.	Refer to #3.	Refer to #3.	Compliant
5	The annual water year for water taken under this licence is defined as 12:00pm at 30 June to 12:00pm at 30 June twelve months later.	N/A	This item has been taken as a note.	Not audited.
6	The licensee must not, in any water year, take more water than the annual water entitlement specified in this licence.	See #3	The licence entitlement is 100,000 kL per year and includes two bores established on the site: Bore 1-meter serial No. 08HC05315 - total water use of 4,607 kL during the audit period. Bore 2-meter serial No. 08HC05638 – total water use is 3,904 kL during the audit period. Total water use for 2018–19 was 8,511 kL which is within the limits of the licence.	Compliant
7	The licensee must take and record the reading from each meter required under this licence at the beginning and another at the end of the water year defined on this licence.	R_006_ERM Power_2018 2019 Bore 1 End of year online readings_29062019 R_007_ERM Power_2018 2019 Bore 2 End of Year online readings_29062019	Water bore records were undertaken at the beginning and the end of the water year for each meter.	Compliant
8	In addition to taking and recording the reading(s) at the beginning and the end of the water year, the licensee must, as close as practicable to the end of each month (other than the month in which the water year ends), take and record the reading from each meter required under this licence.	R_006_ERM Power_2018 2019 Bore 1 End of year online readings_29062019 R_007_ERM Power_2018 2019 Bore 2 End of Year online readings_29062019	All water bore readings were recorded as close as practicable to the end of each month during the reporting period.	Compliant
9	All meter readings must be recorded on the 'Meter Water Use Card'.	R_006_ERM Power_2018 2019 Bore 1 End of year online readings_29062019 R_007_ERM Power_2018 2019 Bore 2 End of Year online readings_29062019 C_004_ERM Power_2019 Water Use Online Submission Email confirmation_15072019	The auditors note that there is now an online system for submission of water meter readings. This system has resulted in duplication of water use records being kept, both through water use cards and online. In email correspondence, DWER confirmed that submission of water use records entries via the only system are satisfactory.	Compliant
10	The completed Water Meter Use Card must be returned to the Department of Water by 7 July each year.	C_004_ERM Power_2019 Water Use Online Submission Email confirmation_15072019	DWER confirmed on the 15 July 2019 that online submission of water meter readings had been received.	Compliant
11	The licensee must notify the Department of Water in writing of any water meter malfunction within seven days of the malfunction being noticed.	Management advice 30 October 2019.	The operator advised that there were no malfunctions during the audit period.	N/A
12	The licensee must obtain authorisation from the Department of Water before removing, replacing or interfering with any meter required under this licence.	Management advice 30 October 2019.	No replacement or interfering of meters was undertaken during the audit period.	N/A


© JBS&G Australia Pty Ltd T/A Strategen-JBS&G

This document is and shall remain the property of Strategen-JBS&G. The document may only be used for the purposes for which it was commissioned and in accordance with the Terms of Engagement for the commission. Unauthorised use of this document in any form whatsoever is prohibited.

Document Distribution

Rev No.	Copies	Recipient	Date
A	1 x Electronic	B Lanciano, ERM Power (for review)	20 December 2019
0	1 x Electronic	B Lanciano, ERM Power (for submission)	6 January 2019

Document Status

Rev No.	Author	Reviewer	Approved for Issue		
		Name	Name	Signature	Date
A	R Mason	K Moyle	K Moyle		20 December 2019




© JBS&G Australia Pty Ltd T/A Strategen-JBS&G

This document is and shall remain the property of Strategen-JBS&G. The document may only be used for the purposes for which it was commissioned and in accordance with the Terms of Engagement for the commission. Unauthorised use of this document in any form whatsoever is prohibited.

Document Distribution

Rev No.	Copies	Recipient	Date
A	1 x Electronic	B Lanciano, ERM Power (for review)	24 December 2019
0	1 x Electronic	B Lanciano, ERM Power (for submission)	6 January 2020

Document Status

Rev No.	Author	Reviewer	Approved for Issue		
		Name	Name	Signature	Date
A	R Mason	K Moyle	K Moyle		20 December 2019

